# LAFAYETTE AIRPORT COMMISSION LAFAYETTE, LOUISIANA

# SPILL PREVENTION, CONTROL AND COUNTERMEASURE PLAN

# **DECEMBER 2013**

Prepared by:

C-K Associates 17170 Perkins Road Baton Rouge, Louisiana 70810 (225) 755-1000

C-K Associates' Project No. 9070

#### MANAGEMENT APPROVAL

Management approval has been extended at a level with authority to commit the necessary resources to implement this Spill Prevention, Control, and Countermeasure (SPCC) Plan. Pursuant to §112.7(d), this is the written commitment of Lafayette Regional Airport (LFT) to provide the manpower, equipment, and materials required to expeditiously control and remove any quantity of oil discharged that may be harmful to human health and the environment. This Plan will be implemented as herein described, and the Plan will be physically maintained by the Lafayette Airport Commission (LAC) at LFT, which is located at 222 Tower Drive in Lafayette, Louisiana.

11. ( ) ( ) ( ) ( )	
Sur M. Koleists	1/2/14
Signature, Authorized Facility Representative	Date
Gregory M. Roberts, A.A.E.	
Printed Name	
Director of Aviation	
Title	
August 16, 2002	
Date of full implementation	
(GR)	*
Management Initials	

C-K Associates

#### **ENGINEER'S CERTIFICATION**

I hereby certify that: (i) I am familiar with the requirements of the SPCC rule [Title 40 Code of Federal Regulations (CFR) Part 112]; (ii) I and my agent have visited and examined the facility; (iii) the plan has been prepared in accordance with good engineering practice, including consideration of applicable industry standards, and with the requirements of the SPCC rule; (iv) the procedures for inspection and testing have been established; and (v) the plan is adequate for the facility, with exceptions as noted below.

Alexander Baron Sheffield, P.E.

Printed Name of Registered Professional Engineer

Signature of Registered Professional Engineer

Registration No. 25165

State LA

## Noted Exceptions

Many bulk storage containers referenced in this SPCC Plan are owned and operated by airport tenants and fixed based operators (FBOs) of the Lafayette Regional Airport. Therefore adherence to the SPCC rule for these containers is not included nor attested to by this certification.

## TABLE OF CONTENTS

Secti	<u>on</u>		<u>Page</u>
Mana	agement	Approval	i
Engi	neer's C	ertification	ii
1.0	INTR	RODUCTION	1
2.0	GEN	ERAL APPLICABILITY	2
3.0	SPCC	C PLAN ADMINISTRATION	3
	3.1	Requirement to Prepare	3
	3.2	Amendment by Regional Administrator	3
	3.3	SPCC Plan Amendment by Owner/Operator	4
	3.4	Qualified Facility Plan Requirements	5
4.0	SPCC	C PLAN GENERAL REQUIREMENTS	6
	4.1	General Facility Information	6
	4.2	General Facility Description	7
	4.3	SPCC Plan Conformance and Deviations	8
	4.4	Facility Layout	9
	4.5	Oil Storage Capacity	9
	4.6	Discharge Prevention Measures	9
	4.7	Discharge or Drainage Controls	10
	4.8	Countermeasures for Discharge Discovery, Response, and Cleanup	17
	4.9	Recovered Materials Disposal	18
	4.10	Contact List and Notification Phone Numbers	18
	4.11	Reporting and Notification Procedures	20
	4.12	Oil Spill Response Procedures	21
	4.13	Discharge Analysis	21
	4.14	Spill Containment	23
	4.15	Spill Containment Practicability	24
	4.16	Inspections, Tests, and Records	24
	4.17	Personnel, Training, and Discharge Prevention Procedures	26
	4.18	Security	27
	4.19	Facility Tank Car and Tank Truck Loading/Unloading Rack	28

	4.20	Brittle Fracture Analysis	28
	4.21	Applicable Requirements	29
	4.22	Qualified Oil-Filled Operational Equipment	31
5.0	RE(	QUIREMENTS FOR ONSHORE (NON-PRODUCTION) FACILITIES	31
	5.1	General	31
	5.2	Facility Drainage	32
	5.3	Bulk Storage Containers	33
	5.4	Facility Transfer Operations, Pumping, and Facility Process	37
6.0	RE(	QUIREMENTS FOR ONSHORE OIL PRODUCTION FACILITIES	39
7.0		QUIREMENTS FOR ONSHORE OIL DRILLING AND WORKOVER CILITIES	
8.0		QUIREMENTS FOR OFFSHORE OIL DRILLING, PRODUCTION, AND RKOVER FACILITIES	
9.0	QUIREMENTS FOR ANIMAL FATS AND OILS AND GREASES, AND FISH D MARINE MAMMAL OILS; AND FOR VEGETABLE OILS, INCLUDING S FROM SEEDS, NUTS, FRUITS, AND KERNELS		
	9.1	General	39
	9.2	Facility Drainage	10
	9.3	Bulk Storage Containers	41
	9.4	Facility Transfer Operations, Pumping, and Facility Process	14
		LIST OF TABLES	
Table 1	I	Regulatory Cross-Reference Comparison	
		LIST OF FIGURES	
Figure 1 2	S	Site Location Map Site Layout, Surface Drainage, and Potential Pollutant Sources	
		LIST OF APPENDICES	
Appen	<u>dix</u>		
A B		Substantial Harm Checklist SPCC Plan Worksheets	
D		B-1 Spill History	

- B-2 Material Inventory
- B-3 Prediction and Control of Potential Discharges
- B-4 Secondary Containment Capacity Calculations
- C Plan Review Certification
  - C-1 Certification of SPCC Plan Review
  - C-2 Record of Plan Review and Change
- D Emergency Response Procedures and Contacts
- E Spill Information Report
- F Inspection Forms
  - F-1 Quarterly SPCC Visual Inspection
  - F-2 Annual SPCC Inspection

#### 1.0 INTRODUCTION

The Federal Water Pollution Control Act (FWPCA), as amended by the Clean Water Act of 1977, authorized the establishment of procedures, methods, equipment, and other requirements for the prevention and/or containment of discharges of oil and hazardous substances from vessels and onshore and offshore facilities. In response to this authorization, the U.S. Environmental Protection Agency (USEPA) issued Oil Pollution Prevention Regulations for Non-Transportation Related Onshore and Offshore Facilities on December 11, 1973 (effective on January 10, 1974). These regulations (herein referred to as the SPCC rule) were published under 40 CF, Part 112 (Oil Pollution Prevention), and specifically outlined requirements for the preparation of SPCC plans.

On July 17, 2002, the USEPA published modifications to the SPCC rule in the Federal Register (Volume 67, No. 137, pages 47041-47152). These changes became effective on August 16, 2002. The SPCC rule has been periodically updated with the most recent update on November 5, 2009. This SPCC Plan is in conformance with the updated SPCC rule.

This Plan also includes a prevention and response plan for release of Comprehensive, Environmental Response, Compensation, and Liability Act of 1980 (CERCLA) hazardous substances and extremely hazardous substances listed under the Superfund Amendments and Reauthorization Act (SARA) Title III, Section 302, for which there is a potential for release above the reportable quantity (RQ) or that are stored above threshold planning quantities.

The following sections of this Plan are presented in the sequence of the SPCC rule. The substantive requirements (§§112.7 and 112.8) are addressed in Sections 4 and 5, respectively. Edible oil requirements are addressed in Section 7. In these sections, the exact wording of the rule is provided in italics, followed by an explanation of how the requirements have been addressed.

Spill response in the State of Louisiana is regulated by two different state agencies: the Louisiana Department of Environmental Quality (LDEQ) and the Louisiana Department of Public Safety and Corrections Office of State Police Emergency Response Commission (LDPS).

Chapter 9 of Title 33, Psart XI of the Louisiana Administrative Code (LAC 33:IX.Chapter 9) contains the LDEQ requirements for contingency planning and implementation of operating procedures and best management practices to prevent and control the discharge of pollutants resulting from spill events.

The federal and state spill regulations each require a specified sequence be followed or a cross-reference be provided indicating where the requirements are met within the plan. Table 1 provides a cross-referencing of federal and state requirements.

LDEQ requires reportable quantities and unauthorized releases be reported in accordance

9070 1 C-K Associates

with LAC Title 33, Part I, Chapter 39. Reportable quantities include one barrel (42 gallons) of oil of any kind onto land including but not limited to petroleum, fuel oil, sludge, oil refuse, and oil mixed with wastes other than dredged spoil. A release of oil into waters of the state that cause a sheen also is reportable. Other RQs for chemicals at the airport may include methyl ethyl ketone (743 gallons); acetone (757 gallons); toluene (138 gallons); and ethylene glycol (537 gallons). In the event of a significant spill or unauthorized release, the following actions are required:

- The permittee must notify LDEQ Office of Environmental Compliance within 24 hours after learning of the release at (225) 765-0634 between 8:00 a.m. and 4:30 p.m., Monday through Friday, or (225) 342-1324; and
- The permittee must notify the National Response Center (NRC) at (800) 424-8802 in accordance with the requirements of 40 CFR 110, 40 CFR 117, and 40 CFR 302, as soon as they acquire knowledge of the release.

Chapter 101 of Title 33, Part V of the LAC (Hazardous Material Information Development, Preparedness, and Response Act) contains the LDPS regulations. The release reporting regulations require that a release of specified substances must be reported immediately if the release meets or exceeds the (release) reportable quantity (RQ) and the release escapes beyond the site of the facility. The release of oils/gasoline/diesel (flammable liquids) in excess of 100 pounds (approximately 13.5 gallons) that leave the site must be verbally reported to the State Police "immediately" (within one hour of discovery) and a written report must be submitted wthin five days.

#### 2.0 GENERAL APPLICABILITY: §112.1

The Oil Pollution Prevention Regulations (40 CFR Part 112) require preparation of an SPCC plan for facilities that have discharged or could reasonably be expected to discharge oil into or upon navigable waters of the United States or adjoining shorelines.

Specifically, §112.1(d)(2)(ii) requires an SPCC plan to be developed for a facility where the aggregate storage capacity of oil is greater than 1,320 gallons. LFT, located in Lafayette, Lafayette Parish, Louisiana, stores an aggregate quantity of oil greater than 1,320 gallons; therefore, the facility is required to develop, implement, and maintain an SPCC plan in accordance with 40 CFR Part 112.

According to LAC 33:IX.903, Louisiana Spill Prevention and Control regulations apply to LFT because the airport stores oil and the minimum aboveground storage capacity at which Chapter 9 applies is exceeded.

This SPCC Plan has been developed for LFT in response to the regulations listed above. The purpose of this Plan is to identify sources of oil at LFT and outline procedures to prevent the discharge of oil and oil products or hazardous substances to navigable waters of the United States. Discharge of oil is specifically prohibited by law if it affects water quality, causes a film, sheen, or discoloration of the water surface or upon water or adjoining shorelines, or causes a sludge or emulsion to be deposited beneath the surface

of the adjoining shorelines. All facilities regulated under 40 CFR Part 112 must conduct an initial screening to determine whether they are required to develop a Facility Response Plan (FRP) under §112.20(e). The Substantial Harm Checklist used to certify that these requirements are not applicable is provided in Appendix A. Because submittal of an FRP is not required, this SPCC Plan provides clear information and procedures for responding to discharges.

#### 3.0 SPCC PLAN ADMINISTRATION: §112.3, §112.4, §112.5, AND §112.6

#### 3.1 Requirement to Prepare: §112.3

LFT was in operation before August 16, 2002. LFT has maintained an SPCC Plan prior to this date. This SPCC Plan was prepared to amend the previous plan maintained at the facility. In accordance with §112.3(a), this Plan was completed and fully implemented prior to November 10, 2011.

In accordance with §112.3(e)(1) and (2), a complete, updated copy of this SPCC Plan will be maintained at LFT. During normal working hours at the airport, the Plan will be available to authorized representatives of local, state, or federal governing agencies for on-site review and a copy will be submitted if requested.

#### 3.2 Amendment by Regional Administrator: §112.4

In accordance with §112.4(a), whenever more than 1,000 gallons of oil have been discharged in a single incident or more than 42 gallons of oil have been discharged in each of two incidents over a 12-month period, LFT will submit the following information to the USEPA Regional Administrator (RA) within 60 days:

- §112.4(a)(1): Facility name;
- §112.4(a)(2): Name of designated person accountable for oil spill prevention at facility;
- §112.4(a)(3): Facility location;
- §112.4(a)(4): Maximum storage capacity and daily throughput at facility;
- §112.4(a)(5): Description of corrective action and countermeasures taken;
- §112.4(a)(6): Adequate description of the facility, including maps and flow diagrams;
- §112.4(a)(7): Cause of the discharge(s), including an analysis of the failed system;

9070 3 C-K Associates

- §112.4(a)(8): Description of additional preventive measures taken or contemplated to prevent recurrence; and
- §112.4(a)(9): Other pertinent information.

In accordance with §112.4, copies of the incident report will also be forwarded to the Louisiana Department of Environmental Quality (LDEQ). Should the RA subsequently propose by certified mail or personal delivery that this SPCC Plan be amended, in accordance with §112.4(e), LFT will:

- Submit arguments and supporting information in response to the proposed amendments; or
- Amend this SPCC Plan within 30 days and implement the amended Plan within 6 months.

As required by §112.3(d), technical changes made to the Plan will be certified by a Professional Engineer.

The airport has not experienced a discharge of 1,000 gallons of oil in a single incident nor have more than 42 gallons of oil been discharged in each of two incidents over a 12-month period. The airport experienced a spill of 100 gallons of Jet A fuel on September 24, 2004. No off-site impacts occurred. The airport experienced a spill of 100 gallons of oil on September 15, 2006. No off-site impacts were experienced. See Appendix B for a record of any spills at the airport. Other than the spills above, the airport has not experienced any significant oil spills in the last 10 years.

#### 3.3 SPCC Plan Amendment by Owner/Operator: §112.5

In accordance with §112.5(a), when there is a change in facility design, construction, operation, or maintenance that materially affects its potential for a discharge, LFT will amend this SPCC Plan within 6 months of the change and implement the amended Plan within 6 months of its completion. Changes that might require amendment of the Plan include commissioning or decommissioning containers; replacement, reconstruction, or movement of containers; construction or demolition that might alter secondary containment structures; changes of product or service; or revision of standard operation or maintenance procedures at a facility. An amendment made under this section must be prepared within 6 months and implemented as soon as possible, but not later than 6 months following preparation of the amendment.

In accordance with §112.5(b), LFT will also review this Plan at least once every 5 years from the date of the last review. As a result of the review, the Plan will be amended within 6 months of the review if more effective prevention and control

technology has been field-proven at the time of the review and will significantly reduce the likelihood of a discharge. The amended Plan will be implemented within 6 months of its completion. The designated person accountable for oil spill prevention at the facility will document completion of each 5-year review, sign a statement as to whether the Plan will be amended, and record the results in Appendix C. Also, see Appendix C for the record of Plan review and changes. As required by §112.3(d), technical changes made to the Plan will be certified by a Professional Engineer.

As required by LAC 33:IX.905(E) and (F), this Plan will be reviewed every 5 years by responsible personnel for conformance with Louisiana Spill Prevention and Control requirements as found in LAC 33:IX Chapter 9. The Plan will be amended within 90 days of the review to include more effective prevention and control technology if such technology for substances subject to LAC 33:IX Chapter 9 will significantly reduce the likelihood of a spill event and if such technology has been field-proven at the time of the review.

#### 3.4 Qualified Facility Plan Requirements: §112.6

- (a) Tier I Qualified Facilities (1) Preparation and Self-certification of Plan. If you are the owner or operator of a facility that meets the qualified facility qualification criteria in  $\S 112.3(g)(1)$ , you must certify in the Plan that:
- (i) You are familiar with the requirements of this part;
- (ii) You have visited and examined the facility;
- (iii) The Plan has been prepared in accordance with accepted and sound industry practices and standards, and with the requirements of this part;
- (iv) Procedures for required inspections and testing have been established;
- (v) The Plan is being fully implemented;
- (vi) The facility meets the qualification criteria set forth under § 112.3(g);
- (vii) The Plan does not deviate from any requirement of this part as allowed by
- §§ 112.7(a)(2) and 112.7(d), except as provided in paragraph (c) of this section; and
- (viii) The Plan and individual(s) responsible for implementing the Plan have the full approval of management and the facility owner or operator has committed the necessary resources to fully implement the Plan.

This section does not apply to the facility because a Registered Professional Engineer is certifying the SPCC.

9070 5 C-K Associates

#### 4.0 SPCC PLAN GENERAL REQUIREMENTS: §112.7

If you are the owner or operator of a facility subject to this part you must prepare a Plan in accordance with good engineering practices. The Plan must have the full approval of management at a level of authority to commit the necessary resources to fully implement the Plan. You must prepare the Plan in writing. If you do not follow the sequence specified in this section for the Plan, you must prepare an equivalent Plan acceptable to the Regional Administrator that meets all of the applicable requirements listed in this part, and you must supplement it with a section cross-referencing the location of requirements listed in this part and the equivalent requirements in the other prevention plan. If the Plan calls for additional facilities or procedures, methods, or equipment not yet fully operational, you must discuss these items in separate paragraphs, and must explain separately the details of installation and operational start-up.

Section 4.0 of this Plan presents facility-specific details associated with the general requirements for SPCC plans outlined in §112.7. As previously indicated in Sections 1 through 3, this SPCC Plan has been prepared in accordance with good engineering practice, with management approval at a level with authority to commit the necessary resources for full implementation, and in the sequence of the rule.

#### **4.1** General Facility Information

Facility Name: <u>Lafayette Regional Airport</u>

Facility SIC Code: 4581

Facility Type: Airports, Flying Fields, and Airport Terminal Services

Facility Location: 222 Tower Drive

Lafayette, Lafayette Parish, Louisiana

Latitude: N 30° 12.2" Longitude W 91° 59.3'

Date of Initial Facility Operation: November 1930

Owner Name and Address: <u>Lafayette Airport Commission</u>

222 Tower Drive

Lafayette, Louisiana 70508-2159

Designated Person Accountable for Oil Spill Prevention at LFT:

Director of Aviation

(337) 266-4401

Designated Environmental Site Leader at LFT:

**Environmental Compliance Officer** 

(337) 266-4484

Designated Persons Responsible for Day-to-Day Monitoring of Activities at LFT:

Deputy Director of Aviation and Operations Specialists

(337) 266-4401

Has facility experienced a reportable oil spill event during the past 12 month? No

#### 4.2 General Facility Description

LFT is located in the eastern portion of Lafayette Parish, Lafayette, Louisiana. According to U.S. Geological Survey topographic map of the Broussard and Lafayette, Louisiana, Quadrangles (1994), the facility lies at an average elevation of 30 feet above mean sea level. Figure 1 depicts the airport location.

LFT is located 2 miles southeast of the city of Lafayette in Lafayette Parish, Louisiana (Figure 1). The facility covers approximately 1,300 acres of land and consists of three asphalt runways: 4,099 feet long by 150 feet wide – running southwest/northeast (Runway 22R); 7,651 feet long by 150 feet wide – running southwest/northeast (Runway 22L); and 5,400 feet long by 150 feet wide – running east/west (Runway 29). The unpaved portions of the property, which lie principally on the western and southern edges of the airport, are covered by grass and small trees. Figure 2 shows the layout of the airport with property boundaries, airport structures, and impervious surfaces.

This airport is classified as a commercial service airport in the Louisiana Airport System and has over 127 based aircraft.

LFT has Jet A, 100 low lead (LL) aviation gasoline (AvGas), gasoline and diesel available for sale and offers major repair and maintenance operations 7 days per week in addition to regular scheduled air passenger service.

The airport is approximately 1,300 acres in size, of which approximately 600 acres are fenced and used as an airport, fly field, and airport terminal services. This SPCC Plan addresses the 600-acre portion and the Airports Maintenance Facility. A number of buildings, T-Hangars, a tower, FBOs, several permanent generators, and numerous aboveground storage tanks (ASTs), are located at LFT. Parking at LFT is located on the northwest area of the airport. Airport operations have been conducted at this property since 1930.

The facility does not produce any chemicals, solutions, or emulsions. Miscellaneous lubricating oils used for maintenance purposes and used oil are

9070 7 C-K Associates

stored in 55-gallon drums and smaller bucket containers in the T-Hangars and various buildings. Waste oil, waste fuels, waste paint, mineral spirits, miscellaneous solvents, degreasers, antifreeze, and soaps are also stored in 55-gallon drums and smaller containers in the T-Hangars and in various buildings. Numerous jet fuel, LL AvGas, gasoline, and diesel ASTs used for airport vehicles and airplanes and helicopters are located throughout the facility. Figure 2 presents a site plan that depicts the location of the fuel storage, oil storage, and other material stored and other pertinent facility features.

#### 4.3 SPCC Plan Conformance and Deviations: §112.7(a)(1) and (2)

(a)(1) Include a discussion of your facility's conformance with the requirements listed in this part.

(a)(2) Comply with all applicable requirements listed in this part. Except as provided in §112.6, your Plan may deviate from the requirements in paragraphs (g),(h)(2) and (3), and (i) of this section and the requirements in subparts B and C of this part, except the secondary containment requirements in paragraphs (c)  $\S\S112.8(c)(2),112.8(c)(11),$ and (h)(1)this section. and 112.9(c)(2),112.10(c),112.12(c)(2), 112.12(c)(11),112.13(c)(2), and 112.14(c),where applicable to a specific facility, if you provide equivalent environmental protection by some other means of spill prevention, control, or countermeasure. Where your Plan does not conform to the applicable requirements in paragraphs (g),(h)(2) and (3),and (i)of this section, or the requirements of subparts B and C of this part, except the secondary containment requirements in paragraphs (c) and (h)(1)of this section, and  $\S\S112.8(c)(2)$ , 112.8(c)(11), 112.9(c)(2), 112.10(c), 112.12(c)(2), 112.12(c)(11), 112.13(c)(2), and 112.14(c), you must state the reasons for nonconformance in your Plan and describe in detail alternate methods and how you will achieve equivalent environmental protection. If the Regional Administrator determines that the measures described in your Plan do not provide equivalent environmental protection, he may require that you amend your Plan, following the procedures in §112.4(d) and (e).

Many of the storage tanks discussed in this SPCC Plan are owned and operated by the tenants and fixed base operators (FBOs) of the LFT. Therefore, an evaluation of spill containment or adherence to the requirements of §112.1(d)(2)(ii) and §112.7 for any tenant or FBOs is not specifically discussed in regards to conformance within this SPCC Plan. See Appendix B-2 for a list of tenants and their storage tanks.

9070 8 C-K Associates

### 4.4 Facility Layout: §112.7(a)(3)

(a)(3) Describe in your Plan the physical layout of the facility and include a facility diagram, which must mark the location and contents of each container. The facility diagram must include completely buried tanks that are otherwise exempted from the requirements of this part under \$112.1(d)(4). The facility diagram must also include all transfer stations and connecting pipes including intra-facility gathering lines that are otherwise exempted from the requirements of this part under \$112.1(d)(11).

Inside the LFT fenced area, petroleum products are stored in an estimated 19 ASTs and 1 underground storage tank (UST), as shown on Figure 2. Outside of the LFT fenced area, petroleum products are stored in an estimated 19 ASTs and 4 USTs, as shown on Figure 2. See Figure 2 for the layout of the facility and see Appendix B (Worksheet #2), for a complete list of location and contents of containers at LFT. Petroleum ASTs addressed by this Plan are described in the following sections.

#### **4.5** Oil Storage Capacity: §112.7(a)(3)(i)

(a)(3) You must also address in your Plan: (i) The type of oil in each container and its storage capacity;

Oil and fuel products stored at LFT include jet fuel, LL AvGas, diesel, gasoline, used oil, lube oil, and hydraulic oil. The airport also stores various solvents in aboveground containers. A summary of the containers, substances, and substance quantities at the airport are provided in Appendix B (Worksheet #2).

#### 4.6 Discharge Prevention Measures: §112.7(a)(3)(ii)

(a)(3) You must also address in your Plan: (ii) Discharge prevention measures including procedures for routine handling of products (loading, unloading, and facility transfers, etc.);

LFT relies on a number of measures to aid in the prevention of a discharge, including:

• LFT is fenced with 19 gates for authorized vehicles and trucks to enter and exit. The gates are kept closed and locked at all times. Five of the gates have card readers for personnel to access the gates. Gates 6, 7, and 10 through 14 are monitored with video surveillance. Security personnel and the fire station are staffed 24 hours per day, 7 days per week. The Lafayette Sheriff's Department is contracted to monitor the airport. The LFT staff is on site Monday through Friday 5 a.m. to 10 p.m. There is a

9070 9 C-K Associates

call-out pager that is manned 24 hours a day. On a typical day, there will be 18 LFT personnel working at the airport site on the day shift;

- The ASTs are either located within external secondary containment or are double-walled tanks;
- The FBO's mobile fueling trucks, the LFT Operations Department, and the Airport Response and Fire Fighting Department (ARFFD) have spill response kits;
- Inspections are conducted to detect and prevent potential spills; and
- Personnel training programs are conducted to teach proper operating procedures and familiarize staff with the contents and use of the SPCC Plan.

#### 4.7 Discharge or Drainage Controls: §112.7(a)(3)(iii)

(a)(3) You must also address in your Plan: (iii) Discharge or drainage controls such as secondary containment around containers and other structures, equipment, and procedures for the control of a discharge;

LFT relies on secondary containment features as well as procedures for the control of discharges and drainage for the facility. These controls include the following:

- Double-walled tanks;
- Concrete secondary containment pads, dikes, spill containment pallets, and curbing;
- Spill response equipment (absorbent materials, booms, shovels, etc.) that can be quickly deployed once a spill or leak is detected;
- Several Safe Drains have been installed near the T-Hangars; and
- Fuel Farm containment areas are locked to insure storm water is inspected before discharge.

Surface water runoff at LFT is collected throughout the airport in catch basins and open and closed drainage ditches (grass swales and culverts). In general, surface drainage then flows into two borrow pits, Bayou Tortue, Bayou Vermilion, and the Vermilion River. The two borrow pits then discharge into Bayou Tortue. Bayou Tortue flows to the north around the facility into the Vermilion River.

LFT owns and operates six wash racks, which are described below and shown on

Figure 2. These six wash racks are covered by LDEQ's General Permit for Exterior Vehicle Wash Wastewater (No. LAG750655).

- Outfall 001A is Landmark Wash Rack #1 and is located west of Landmark building. This rack is used to wash aircraft and vehicles. This outfall eventually drains to Outfall 002.
- Outfall 001B is Landmark Wash Rack #2 and is located between Landmark hangars #10 and #11. This rack is used to wash aircraft and vehicles. This outfall eventually drains to Outfall 011.
- Outfall 001C is located near the Acadian Ambulance hangar and is used to wash vehicles and helicopters. This outfall eventually drains to Outfall 011.
- Outfall 001D is located east of the LFT Maintenance Shop and is used to wash vehicles and equipment. This outfall eventually drains to Outfall 002.
- Outfall 001E is located by the ARFFD building and is utilized to wash vehicles. This outfall eventually drains to Outfall 011.
- Outfall 001F is located by Gate 7 and is utilized to wash aircraft, helicopters, and vehicles. This outfall eventually drains to Outfall 011.

Ten storm water outfalls have been identified at the airport and are depicted on Figure 2. The outfalls are located throughout the facility and are permitted and covered by LPDES Multi-Sector General Permit (MSGP) Number LAR05M152 and LPDES Small Municipal Separate Storm Sewer Systems Permit Number LAR041025. See below for a description of each outfall:

- Outfall 002 receives runoff from the north side of the property, including the fuel farm and T-Hangars. Outfall 002 discharges into the Vermilion River.
- Outfall 003 receives runoff from the north end of Runway 22R, the north end of Taxiways L and J, and the north end of the perimeter road. Outfall 003 discharges into the Vermilion River.
- Outfall 004 receives runoff from the northeast end of Runway 22L and Taxiway J. Outfall 004 discharges into the Vermilion River to the east.
- Outfall 005 receives runoff from the northeast end of Runway 22L and the perimeter road. Outfall 005 discharges into an open ditch that drains into Bayou Tortue and then into the Vermilion River.

9070 11 **C-K Associates** 

- Outfall 006 receives runoff from the smaller borrow pit. The borrow pit receives runoff from the perimeter road, the middle of Runway 22L, the north end of Taxiway F, and Taxiway B. Outfall 006 discharges into Bayou Tortue and then into the Vermilion River.
- Outfall 007 receives runoff from the northeast side of Runway 29. Outfall 007 discharges into Bayou Tortue and then into the Vermilion River.
- Outfall 008 receives runoff from the southwest side of Runway 29. Outfall 008 discharges into Bayou Tortue and then into the Vermilion River.
- Outfall 009 receives runoff from the larger borrow pit. The borrow pit receives runoff from the south end of Runway 22L, Taxiway H and cargo apron, and the south end of Taxiways J and F. Outfall 009 discharges into Bayou Tortue and then into the Vermilion River.
- Outfall 010 receives runoff from the helipads, the Private Aircraft Hangar fuel farm, and the abandoned Taxiway X. Outfall 010 discharges into an open ditch along U.S. Highway 90 and eventually drains into the Vermilion River to the west.
- Outfall 011 receives runoff from the northwest end of Runway 29, the deicing area, the terminal area, and Acadian Ambulance's Fuel Tank area. Outfall 011 discharges into an open ditch along U.S. Highway 90 and eventually drains into the Vermilion River to the west.

There are many areas within the airport that contain fuel and oil storage, as indicated on Figure 2. See below for descriptions of these storage areas:

- Aircraft, Runway, Ground Vehicle, and Equipment Maintenance Areas Due to the cleaning and maintenance activities that occur at several of LFT tenant facilities, and at Lafayette Maintenance Shop, the potential for spills and non-storm water discharges exists. Most of these activities are performed indoors or under covered roofs to prevent contact with storm water. Recovery of solvents, waste fuels and oils, and other potential pollutant sources (fuel filters, oil filters, etc.) is performed by containing and storing the materials in dedicated drums and tanks for off-site removal.
- Aircraft, Runway Deicing/Anti-icing Operations Although LFT very infrequently utilizes deicing fluids due to its location in southern Louisiana, deicing equipment is available at the airport for each of the carriers. Deicing normally occurs on the carrier apron in front of the terminal (Figure 2). The amount of deicing fluid is typically less than 500 gallons per year; therefore, the risk of contaminating storm water is

9070 12 C-K Associates

considered to be minimal. The table below provides a summary of deicing materials.

Deicing Materials				
Name of Company	Storage of Deicer	Amount	Application	Type of Deicer
Continental Express (COEX)	By Terminal Building Baggage Area	4 Drums (55 gallons each)	Has a machine to apply deicer	Octaflo EF Concentrate, Type I
Delta	By Terminal AC Parking Area	2 Totes (275 gallons each)	Has a machine to apply deicer	Dow-UCAR <sup>TM</sup> PG Aircraft Deicing Fluid Concentrate
FedEx	By Building 29	5 Totes (265 gallons each)	Stored in the deicing truck	KilFrost DF Plus (88) Dilute, Type I
American Eagle	By Gate 10	2 Totes (275 gallons each)	Has a machine to apply deicer	Dow-UCAR™ PG Aircraft Deicing Fluid Concentrate

**Material Storage Areas** - LFT and its tenants store soaps, degreasers, oils, paints, and other chemicals for operation and maintenance of aircraft and supporting vehicles/equipment. Most of the material storage occurs indoors and, therefore, presents little risk of spills and exposure to storm water.

**Transformers -** LAC owns one transformer with an oil quantity greater than 55 gallons. It is located in a vault building near Gate 4B. The transformer contains 55 gallons of oil. If the transformer were to leak, the oil would be contained in the vault building.

Tank Storage Area - LFT has one primary fuel farm area managed by Landmark, where the bulk of its tank storage volume capacity is contained. A second private fuel farm is managed by Private Aircraft Hangar and a third is managed by Acadian Ambulance. These areas either contain double-walled tanks or have sized secondary containment with valves that stay locked and shut until manually opened. The storm water inside Landmark's fuel farm containment area collects in two oil/water separators (OWSs) and these two OWSs are gradually drained. Fuel mats or microblaze are placed inside the containment area to absorb any free-flowing fuel, if needed. Private Aircraft Hangar also operates a small OWS. Acadian has a double-walled tank. When containment area storm water is drained, it flows through the OWS, then through Outfall 010. Other tank storage areas typically consist of double-walled tanks, emergency generators, and fuels, but some waste oils and fuels are stored within secondary containment areas.

**Fueling Areas** - Due to the aircraft and vehicle fueling activities that take place at LFT on a daily basis, there exists the potential for spills to occur. Records for the

9070 13 C-K Associates

fuel farms including maintenance operations and fueling records are not maintained by LFT. The FBO is responsible for maintaining logs and records of all fueling/defueling operations and maintenance activities. This airport handles Jet A fuel, 100 LL AvGas, diesel fuel for maintenance vehicles, and various The Fuel Farm Operators at LFT are quantities of automotive gasoline. Landmark, Acadian Ambulance (private) and Private Aircraft Hangar. Landmark operates a large fuel farm with four 15,000-gallon Jet A ASTs, one 15,000-gallon AvGas AST, two 500-gallon waste fuel ASTs, one 500-gallon gasoline AST, and one 550-gallon off-road diesel AST. The fuel farm tanks are owned by LFT. Four mobile refueler trucks of varying capacity deliver the fuel to the aircraft. No significant spills or leaks have occurred. Acadian Ambulance operates a 10,000 Jet Fuel AST. Private Aircraft Hangar operates private fuel farm with a 2,000gallon AvGas AST, two 10,000-gallon Jet A ASTs, and a 275-gallon waste fuel AST. Water that is not normally associated with normal storm water discharges should, at a minimum, be visually inspected by the Fuel Farm Operator prior to release from the fuel farm containment area. Visual inspection should include color, turbidity, smell, and sheen. See LFT's Storm Water Pollution Prevention Plan (SWPPP) for additional details regarding the inspection process. Once the visual inspections indicate that the water is contamination free, it is discharged to the airport drainage system. If there is any indication that the water is not suitable for discharge, the oil is removed or storm water will be collected and disposed of off-site.

Other private companies also operate fuel storage facilities at the airport. Below is a list of items the tenants are storing inside the airfield's fence:

- 1. <u>Acadian Ambulance</u> stores minimal amounts of miscellaneous soaps, solvents, and oil in a flammable locker inside their building. They also store a 275-gallon used oil tote, several drums of soaps, oils, and degreasers, and have a 10,000-gallon AST of Jet A with their own SPCC Plan.
- 2. <u>Frank's Casing Crew</u> operates one 12,000-gallon UST with Jet A fuel. The tank is registered with LDEQ. No spill information has been provided. Frank's also stores four drums of used oil, hydraulic oil, varsol, and lube oil, which are stored in enclosed stainless steel secondary containment.
- 3. <u>Federal Aviation Administration (FAA)</u> has one 2,000-gallon diesel AST to be used with the emergency generator during times of power outages. The AST is a double-walled steel tank. The FAA has its own SPCC Plan.
- 4. <u>Landmark</u> has one out-of-service 12,000-gallon double-walled AvGas AST located uphill from the fuel farm. Landmark has four mobile refueler trucks (three 5,000-gallon Jet Fuel and one 1,000-gallon Avgas) to deliver fuel to aircraft and equipment. Landmark also has one mobile refueler with one 100-gallon gasoline AST and one 100-gallon diesel AST. Landmark also stores minimal amounts of miscellaneous soaps, paints, solvents, oil, and hydraulic

9070 14 C-K Associates

oil in drums on a containment pallet inside their building. Landmark's subtenant Nobel Flight has a 500-gallon used oil storage tank and stores miscellaneous soaps, paints, solvents and oil in drums and smaller containers in their area either in a storage room or on containment pallets. These ASTs and mobile refuelers are covered under Landmark's SPCC Plan.

- 5. <u>Lafayette ARFFD</u> has three ASTs: one 500-gallon double-walled diesel AST, one 500-gallon double-walled gasoline AST, and one 500-gallon double-walled waste oil AST. These ASTs are owned by LAC and operated by ARFF. They are covered under this SPCC Plan.
- 6. <u>United Parcel Service (UPS)</u> has one 900-gallon double-walled waste oil tank and several drums on a containment pallet of oil filters, fuels, etc.
- 7. <u>Private Aircraft Hangar of Lafayette</u> has two 10,000-gallon Jet A Fuel ASTs, one 2,000-gallon Av Gas AST, and one 275-gallon AST for waste fuel. The four ASTs are located in a concrete secondary containment berm. The ASTs are covered under the Private Hangar's SPCC Plan.

See below for a list of items the tenants are storing outside the airfield's fence but still on LFT's property:

- 1. <u>Lafayette Airport Maintenance</u> has one double-walled 500-gallon AST for diesel storage, one 500-gallon double-walled gasoline AST, one 500-gallon double-walled waste oil tank, and three flammable lockers that contain minimal amounts of soaps, paints, and oil. Lafayette Airport Maintenance has not reported any spills. The ASTs are covered under LAC's SPCC Plan.
- 2. Avis Rent-a-Car Company has one 5,000-gallon double-walled AST for gasoline and a few drums of oil and soap. The AST is double-walled. Avis has not reported any significant fuel spillage. The AST is covered under Avis's SPCC Plan.
- 3. <u>Brenton Investments (Shell Gas Station)</u> has one 10,000-gallon UST and two 6,000-gallon USTs that store gasoline and one 6,000-gallon diesel UST. The USTs are steel tanks that are lined for leak protection. The tanks are registered with LDEQ.
- 4. The Marine Survival Training Center has one 500-gallon oily water AST, one 250-gallon diesel AST and two drums of miscellaneous fuels and oil. All containers are located in concrete containment. The Center has not reported any significant fuel spills. The Facility did have a small spill that was reportable because oil spilled into the Airport's Larger Lake causing a sheen. The hydraulic lift used to move boat into and out of the lake blew a hydraulic line causing oil to enter the water. The proper authorities were notified by

9070 15 C-K Associates

MSTC and the spill was cleaned up.

- 5. Moss Motors no longer does maintenance at the Facility. Moss Motors also has a flammable locker that contains small containers of lubricants, paints, and soaps.
- 6. Petroleum Helicopters, Inc. (PHI), Heliport has two 10,000-gallon ASTs containing Jet A fuel. There is secondary containment for these tanks and an SPCC Plan. One 500-gallon waste oil double-walled tank is available on site. One 2,000-gallon and one 1,000-gallon mobile fuel truck deliver fuel to aircraft. These trucks are housed at the PHI Main Facility when not in use. PHI also has several drums of WD-40, used oil, hydraulic fluid, and methyl ethyl ketone stored on spill containment pallets. PHI had several fuel spills over the last 3 years due to overfilling of a fuel truck, a fuel hose rupture, and an accidental release when defueling aircraft. AST's are covered under PHI's SPCC Plan.
- 7. PHI Main Facility has one 300-gallon AST for waste kitchen grease, one 500-gallon AST for jet fuel, one 1,000-gallon AST for jet fuel, and one 1,000-gallon AST for diesel. PHI also has several drums of used oil, fuel, and hazardous materials. All drums are located within containment. AST's are covered under PHI's SPCC Plan.
- 8. <u>Louisiana Army National Guard (LANG)</u> has one 1,000-gallon used oil AST and one 4,500-gallon diesel AST. Both of the ASTs are double-walled steel tanks. In addition, LANG has one 1,200-gallon mobile refueler for diesel. LANG also has approximately four drums of oil and antifreeze stored on spill containment pallets. LANG ASTs are covered under their own SPCC Plan.
- 9. <u>U.S. Navy/Marine Reserves</u> has approximately five drums of oil, antifreeze, and transmission oil stored on spill containment pallets.
- 10. <u>ULL Water Ski Team</u> operates one 250-gallon gasoline AST in containment. ULL Water Ski Team has not reported any significant fuel spillage.
- 11. <u>Vermilionville</u> has one 500-gallon AST of diesel fuel, one 275-gallon used oil AST, and a maximum of six drums of fuel (diesel or gas).
- 12. Federal Aviation Administration (FAA) has two 2,000-gallon diesel ASTs and one 1,000 diesel AST for fueling emergency generators during times of power outages. The AST are all double-walled concrete tanks. The FAA has its own SPCC Plan.
- 13. <u>Louisiana Technical College Lafayette</u> has approximately five drums of paint wastes, oil, fuel, and hydraulic fluid stored inside their building on

9070 16 **C-K Associates** 

containment pallets.

14. <u>Terminal Restaurant</u> has one 250-gallon AST of used cooking oil at the west end of the Terminal Building.

See Appendix B (Worksheet #2), for a complete list of the material inventory at the airport.

# 4.8 Countermeasures for Discharge Discovery, Response, and Cleanup: §112.7(a)(3)(iv)

(a)(3) You must also address in your Plan: (iv) Countermeasures for discharge discovery, response, and cleanup (both the facility's capability and those that might be required of a contractor);

It is the responsibility of each employee at the airport to assist in spill prevention by being observant for signs of potential spills. Personnel at the airport may reduce or eliminate the risk of spills by taking direct action to correct the potential spill situation or referring the problem to the Environmental Site Leader or their designee.

Visual inspections of the storage tanks are conducted a minimum of once per shift for signs of deterioration or leaks. If deficiencies are observed, the Environmental Site Leader is contacted and proper corrective measures are followed. In addition to the routine daily visual inspections, spill response equipment and secondary containment structures are regularly inspected.

Spill kits containing absorbent pads and socks are located at the ARFFD. The FBO Landmark as well as LAC Operations Department have spill kits located inside their trucks. Spill kits are also stored at both fuel farms.

The airport has adequately trained personnel and equipment to contain and clean up minor to moderate volumes of spilled materials. The airport has a Spill Response Team (the ARFFD and Environmental Compliance Officer) that is specifically trained to respond, contain, and clean up minor volumes of spilled materials. On-site equipment and materials include, but are not limited to, spill kits, shovels, squeegees, dirt, sand, visqueen, some absorbent materials (towels, mops, etc.), a front-end loader, three tractors, two sweeper trucks, and two 4X4 Gator golf carts. The airport keeps an empty drum on hand for collecting spill cleanup materials.

Larger spills are controlled through permanent structures such as containment dikes around the fuel farm. If necessary, temporary structures such as booms or earthen berms can be rapidly deployed or constructed to contain larger spills/releases. In case of a large spill, specific response procedures have been developed (Section 4.11 and Appendix D).

#### 4.9 Recovered Materials Disposal: §112.7(a)(3)(v)

(a)(3) You must also address in your Plan: (v) Methods of disposal of recovered materials in accordance with applicable legal requirements;

Materials recovered during a spill event will be appropriately containerized. Soils and other solids will be placed in 55-gallon drums or roll-off containers, as warranted. Liquids will be placed in 55-gallon drums or will be collected in a tank truck using industrial power vacuuming. Recovered materials will be labeled, characterized, and disposed/recycled in accordance with applicable federal, state, and local regulations. The Environmental Site Leader will be responsible for arranging the proper disposal of used spill cleanup materials. All of the spilled materials shall be cleaned up or disposed as required by appropriate regulations.

#### 4.10 Contact List and Notification Phone Numbers: §112.7(a)(3)(vi)

(a)(3) You must also address in your Plan: (vi) Contact list and phone numbers for the facility response coordinator, National Response Center, cleanup contractors with whom you have an agreement for response, and all appropriate Federal, State, and local agencies who must be contacted in case of a discharge as described in §112.1(b).

The Environmental Site Leader is responsible for determining if a spill must be reported to federal, state, or local regulatory agencies. The individual contacting the regulatory agency should ask if other agencies should be notified and if written confirmation of the spill is required. The name and title of the regulatory agency employee accepting the report and the report number should be recorded on a copy of the Spill History form (Appendix B-1) and the Spill Information Report (Appendix E).

If this airport, or one of its tenants, released a listed hazardous substance to the environment in excess or equal to reportable quantities, the following actions are required:

- The permittee must notify the National Response Center at (800) 424-8802, in accordance with the requirements of 40 CFR 110, 40 CFR 117, and 40 CFR 302, as soon as they acquire knowledge of the release. Releases are defined to include any spilling, leaking, pumping, pouring, emitting, emptying, discharging, injecting, escaping, leaching, dumping, or disposing into the environment;
- The permittee must notify the Louisiana State Police at (225) 925-6595 within 1 hour, in accordance with the requirements, as soon as they acquire knowledge of the release;
- In the event of a non-emergency, as defined in LAC 33:I.3917, LDEQ will

be notified in accordance with applicable regulations. Reporting can be accomplished by one of the following methods: fill out a report online at <a href="http://www.deq.louisiana.gov/apps/forms/irf/forms/">http://www.deq.louisiana.gov/apps/forms/irf/forms/</a>, or send an email to <a href="majore@la.gov">spoc@la.gov</a>, or make a verbal notification by calling the LDEQ Single Point of Contact (SPOC) at (225) 342-1234 as soon as possible; and

• Contact the Lafayette Parish Local Emergency Planning Committee per Emergency Response Procedures and Contacts (Appendix D) at (337) 236-5895.

The Environmental Site Leader or his designee must report to the above agencies any spill that causes a release of harmful quantities of oil into navigable waters or their tributaries. Harmful quantities are defined as sufficient oil to exceed water quality standards, cause a sheen or film on the water surface, or cause a sludge or emulsion beneath the water surface.

The Environmental Site Leader or his designee will be responsible for preparing spill reports for the regulatory agencies. A report will be submitted to the USEPA and LDEQ within 60 days of a spill that meets one of the following requirements:

- A spill of 1,000 gallons or more in a single discharge to navigable waters;
   or
- More than 42 gallons in each of two discharges within any 12-month period.

The report will include:

- Name of the facility;
- Owner/operator;
- Facility location;
- Maximum storage or handling capacity at the facility and normal daily throughput;
- Corrective action and countermeasures taken;
- Description of facility including maps, flow diagrams, and topographical maps, as necessary;
- Cause of the discharge including system failure analysis;
- Preventive measures taken or contemplated to minimize the possibility of

recurrence; and

• Any other pertinent information.

The contact list and notification phone numbers and requirements are outlined in the Emergency Spill Response Procedures and Contacts, which are provided in Appendix D. A Spill Information Report will be completed. A Spill Information Report is provided in Appendix E.

#### 4.11 Reporting and Notification Procedures: §112.7(a)(4)

(a)(4) Unless you have submitted a response plan under §112.20, provide information and procedures in your Plan to enable a person reporting a discharge as described in §112.1(b) to relate information on the exact address or location and phone number of the facility; the date and time of the discharge, the type of material discharged; estimates of the total quantity discharged; estimates of the quantity discharged as described in §112.1(b); the source of the discharge; a description of all affected media; the cause of the discharge; any damages or injuries caused by the discharge; actions being used to stop, remove, and mitigate the effects of the discharge; whether an evacuation may be needed; and, the names of individuals and/or organizations who have also been contacted.

Spills or releases of oil that occur at LFT will be documented and reported internally. In addition, spills that meet the criteria for a "reportable spill" must be reported to the regulatory agencies within the time frames discussed above. In certain cases, a written report must be provided to those agencies within the time limits specified in the table above.

Immediately after detecting a spill or leak, personnel will attempt to stop the source of the spill and then contact the Environmental Site Leader. Other personnel will be alerted of the spill and its location and personnel in the immediate vicinity of the spill will attempt to prevent oil from flowing into a surface water body and/or off the airport property. See Appendix E for a copy of the Spill Information Report. As much of the following information as possible should be provided:

- Location of spill;
- Approximate rate and size of the spill;
- Type of material spilled;
- Surface on which the oil spilled (pavement, soil, etc.);
- Amount of time before the spill will flow into a storm sewer inlet or other

drainage pathway;

- Cause of the spill;
- Any damages or injuries caused by the spill;
- Actions taken to mitigate the spill;
- If an evacuation will be required; and
- Any details to assist in determining corrective actions.

Reporting and notification requirements are outlined in the Emergency Response Procedures for spills, which are provided in Appendix D. A Spill Information Report will be completed. A copy of the Spill Information Report is provided in Appendix E. All spills that have occurred which are reportable to a regulatory agency will be recorded on the Spill Information Report and filed in Appendix E. Copies of these records will be maintained on site.

#### 4.12 Oil Spill Response Procedures: §112.7(a)(5)

(a)(5)Unless you have submitted a response plan under §112.20, organize portions of the Plan describing procedures you will use when a discharge occurs in a way that will make them readily usable in an emergency, and include appropriate supporting material as appendices.

The Emergency Response Procedures for spills at LFT are provided in Appendix D.

#### 4.13 Discharge Analysis: §112.7(b)

(b) Where experience indicates a reasonable potential for equipment failure (such as loading or unloading equipment, tank overflow, rupture, or leakage, or any other equipment known to be a source of a discharge), include in your Plan a prediction of the direction, rate of flow, and total quantity of oil which could be discharged from the facility as a result of each type of major equipment failure.

Pursuant to §112.7(b), predictions of the direction, rate of flow, and total quantity of material that could be discharged at the airport are summarized below. Natural drainage patterns and surface water features at the site are depicted on Figure 2. The nearest surface water features are the two borrow pits, Bayou Tortue, Bayou Vermilion, and the Vermilion River.

Based on the materials stored and processes utilized at the airport, spill mitigation procedures and response guidelines address the following scenarios:

- Rupture or leaks from the storage tanks;
- Tank overfill/failures;
- Rupture of a fill line or broken connection during filling of the storage tank from a tank truck;
- Rupture or leaks from the oil piping, pumps, and associated equipment;
   and
- Overturned, leaking, or punctured drums.

The potential for a major spill to impact state waters is low because:

- There are multiple layers of containment;
- LFT's storm drains are designed to capture spilled material;
- Vehicular traffic/raw material delivery/product shipment is restricted; and
- Employees are well trained in the airport operation and procedures.

Predictions of the direction, rate of flow, and total quantity of material that could be discharged from the airport storage and non-storage areas are presented in Appendix B (Worksheet #3).

The following scenarios were evaluated for discharge potential and substance amount:

Discharge Scenario	Material	Planning Volumes
Small/Average	Diesel/Oil/Solvents/Deicing	5 gallons
Medium	Jet Fuel/LL AvGas/Diesel	3,000 gallons
Large/Worst Case	Jet Fuel/LL AvGas/Diesel	15,000 gallons

The following operations have been evaluated considering spill history, age of equipment, chain reaction failure probability, and proximity to property limits in relation to flow direction in selecting small, medium, and worst case discharge scenarios:

Operation	Discharge Scenario
Aircraft, Runway, Ground Vehicles,	Small/Average
and Equipment Maintenance Areas	
Deicing Activities	Small/Average
Refueling and Defueling of Aircraft	Medium
Storage Tanks	Large/Worst Case

9070 22 C-K Associates

The chances of catastrophic failure of the storage tanks are remote. Stored materials include jet fuel, LL AvGas, diesel, gasoline, hydraulic oil, lube oil, and used oil, which are non-corrosive materials. All storage tanks are double-walled or located within containment walls, thus reducing the potential for spills. The fuel farm ASTs are located within containment walls. A tank inspection program further reduces the chances of rupture. In addition, LFT has not experienced a AST rupture during its history of operation.

#### **4.14 Spill Containment:** §112.7(c)

(c)Provide appropriate containment and/or diversionary structures or equipment to prevent a discharge as described in §112.1(b). The entire containment system, including walls and floor, must be capable of containing oil and must be constructed so that any discharge from a primary containment system, such as a tank or pipe, will not escape the containment system before cleanup occurs. At a minimum, you must use one of the following prevention systems or its equivalent: (1)For onshore facilities: (i)Dikes, berms, or retaining walls sufficiently impervious to contain oil; (ii)Curbing; (iii) Culverting, gutters, or other drainage systems; (iv)Weirs, booms, or other barriers; (v)Spill diversion ponds; (vi)Retention ponds; or (vii)Sorbent materials.

(2) For offshore facilities: (I) Curbing or drip pans; or (ii) Sumps and collection systems.

Spill kits containing absorbent pads and socks are located at the ARFFD. Landmark has spill kits located inside their mobile refueling trucks. Landmark and Private Aircraft Hangar have spill kits in their fuel farms. LAC also has spill cleanup materials in Operations Department vehicles.

This combination of double-walled tanks and tanks within containment walls is deemed appropriate for the facility given the:

- Close proximity of spill response contractors;
- LFT's storm drains being adequately sized to contain a spill;
- Commitment of manpower and personnel to deploy in the event of a release; and
- Frequent (once per shift) inspections that occur throughout the airport.

9070 23 C-K Associates

#### 4.15 Spill Containment Practicability: §112.7(d)

(d)If you determine that the installation of any of the structures or pieces of equipment listed in paragraphs (c) and (h)(1) of this section, and \$112.8(c)(2), 112.8(c)(11), 112.9(c)(2), 112.10(c), 112.12(c)(2), 112.12(c)(11), 112.13(c)(2), and 112.14(c) to prevent a discharge as described in \$112.1(b) from any onshore or offshore facility is not practicable, you must clearly explain in your Plan why such measures are not practicable; for bulk storage containers, conduct both periodic integrity testing of the containers and periodic integrity and leak testing of the valves and piping; and, unless you have submitted a response plan under \$112.20, provide in your Plan the following:

(1)An oil spill contingency plan following the provisions of part 109 of this chapter.

(2)A written commitment of manpower, equipment, and materials required to expeditiously control and remove any quantity of oil discharged that may be harmful.

No discussion related to practicability is warranted for structures addressed in the referenced regulatory sections.

#### 4.16 Inspections, Tests, and Records: §112.7(e)

(e)Inspections, tests, and records. Conduct inspections and tests required by this part in accordance with written procedures that you or the certifying engineer develop for the facility. You must keep these written procedures and a record of the inspections and tests, signed by the appropriate supervisor or inspector, with the SPCC Plan for a period of three years. Records of inspections and tests kept under usual and customary business practices will suffice for purposes of this paragraph.

LFT maintains a thorough preventive maintenance program to detect faults in all of its storage tanks. LFT's inspection program is based on the Steel Tank Institute Standard for the Inspection of Aboveground Storage Tanks (SP001). Regular inspections are conducted to identify and correct problems before spills occur. Visual inspections are made by operating personnel during their daily rounds to observe signs of deterioration, potential leaks, and the accumulation of material in the curbed areas. A formal visual external inspection of the tanks is conducted monthly. See Appendix F-1 for a copy of the blank form. Once the inspections have been conducted and the forms are completed, a copy will be maintained in LFT's environmental files. A formal tank inspection is conducted annually. See Appendix F-2 for a copy of the blank form. Once the inspections have been conducted and the forms are completed, a copy will be maintained in LFT's environmental files.

All signs of leakage or potential leakage are reported to the Environmental Site Leader or his designee. These inspections are performed on a routine basis.

9070 24 C-K Associates

Maintenance records are kept of all periodic integrity testing as well as other work on the vessels and equipment for a period of not less than 3 years at the airport.

Water that is not normally associated with normal storm water discharges should be inspected prior to release from the fuel farm containment area. At a minimum, the water should be visually inspected. A visual inspection should include color, turbidity, smell, and sheen. See LFT's SWPPP. Once the visual inspections indicate that the water is contamination free, it is discharged to the airport drainage system. If there is any indication that the water is not suitable for discharge, oil will be removed from water or the storm water will be collected and disposed of off-site.

Tank integrity inspections and testing will be accomplished primarily by visual inspections of the tanks, containments, and foundations. Once the inspections have been conducted and the forms are completed, a copy will be maintained in LFT's environmental files. Individual tenants are responsible for maintaining their own testing results and data. Inspections and other integrity testing (as appropriate) will be in accordance with the procedures in API Standard 653 – Tank Inspection, Repair, Alteration, and Reconstruction, or equivalent testing procedures or Steel Tank Institute Standard SP001 – Standard for the Inspection of Aboveground Storage Tanks. Under the Steel Tank Institute Standard SP001, visual inspections by a certified inspector must be conducted every twenty years for tanks greater than 5,000 gallons but less than or equal to 50,000 gallons. There are no tanks greater than 50,000 gallons at the airport.

Completed inspection forms and training records are stored on site in LFT's environmental files. Copies of all forms and logs will be kept in the airport file for at least 3 years. The airport maintains the following records related to oil and hazardous materials for storage, transfer, and training:

- Inspections Results of the inspection and testing of oil storage containers and areas, aboveground piping, and appurtenances (Appendix F and environmental files);
- Storm Water Discharge Dates and times of accumulated storm water discharged from containment areas. See the SWPPP;
- Personnel Training Record Dates and types of SPCC training given to airport personnel and tenants (environmental files); and
- Spill History Record of regulatory agency reportable spills that occur at the airport (Appendix B-1).

9070 25 C-K Associates

#### 4.17 Personnel, Training, and Discharge Prevention Procedures: §112.7(f)

- (f) Personnel, training, and discharge prevention procedures.
- (1) At a minimum, train your oil-handling personnel in the operation and maintenance of equipment to prevent discharges; discharge procedure protocols; applicable pollution control laws, rules, and regulations; general facility operations; and, the contents of the facility SPCC Plan.
- (2) Designate a person at each applicable facility who is accountable for discharge prevention and who reports to facility management.
- (3) Schedule and conduct discharge prevention briefings for your oil-handling personnel at least once a year to assure adequate understanding of the SPCC Plan for that facility. Such briefings must highlight and describe known discharges as described in §112.1(b) or failures, malfunctioning components, and any recently developed precautionary measures.

Airport personnel and tenants will be trained to be familiar with the SPCC Plan. The Environmental Site Leader or his designee is responsible for implementing and maintaining the SPCC Plan. The Environmental Site Leader will periodically review and update the SPCC Plan, including spill response procedures, and is responsible for arranging annual SPCC training sessions for existing tenants and employees and initial training for new employees and tenants. Any changes to the SPCC Plan will be documented in Appendix C-2.

Annual training for personnel handling oil and hazardous materials is conducted by the Environmental Site Leader or his designee to inform personnel of spill prevention equipment and procedures described in this SPCC Plan. All personnel are trained in the general orientation and operation of the airport prior to working at LFT.

Training emphasizes the following information:

- Contents of the SPCC Plan:
- Requirements of the SPCC regulations and other applicable pollution control laws, rules, and regulations;
- Standard Operating Procedures used to prevent discharges of oil and hazardous materials;
- Visual observation during normal operations to detect the first indications of a leak or spill; and
- Descriptions of past spill events, any currently malfunctioning components, and all recently developed precautionary measures.

9070 26 C-K Associates

Employees and tenants will be trained in the Annual SPCC Refresher Course to report, contain, control, and clean up oil spills. Once the training has been provided to each employee and tenant by the Environmental Site Leader or his designee, the signed training forms will be maintained in LFT's environmental files. The date of training, type of training (Initial SPCC or SPCC Refresher training), instructor, and names of individuals attending will be recorded.

Training will be conducted annually or whenever new spill regulations are promulgated, existing operating systems are modified, personnel responsibilities are changed, or the SPCC Plan is amended. In addition, safety meetings will continue to be used as a forum to ensure understanding of SPCC procedures. Training records will be maintained for a period of no less than 3 years.

#### 4.18 Security: §112.7(g)

(g) Security (excluding oil production facilities). Describe in your Plan how you secure and control access to the oil handling, processing and storage areas; secure master flow and drain valves; prevent unauthorized access to starter controls on oil pumps; secure out-of-service and loading/unloading connections of oil pipelines; and address the appropriateness of security lighting to both prevent acts of vandalism and assist in the discovery of oil discharges.

LFT is fenced with 19 gates for authorized vehicles and trucks to enter and exit. The gates are kept closed and locked at all times. Five of the gates have card readers for personnel to access the gates. Gates 6, 7, and 11 through 14 are monitored with video surveillance. Security personnel and the fire station are staffed 24 hours per day, 7 days per week. The Lafayette Sheriff's Department is contracted to monitor the airport. The LFT staff is on site Monday through Friday, 5 a.m. to 10:00 p.m. There is a call-out pager that is manned 24 hours a day. On a typical day, there will be 18 LFT personnel working at the airport site on the day shift.

The starter control on each pump is locked in the "off" position when the pump is in a non-operating or non-standby status. Loading/unloading connections are securely capped or blank-flanged when they are not in service or when they are in standby service for an extended time.

Lighting is provided in all areas of the airport. This lighting is sufficient to provide for the detection of spills during darkness and should deter acts of vandalism that could otherwise result in oil spills.

9070 27 C-K Associates

#### 4.19 Facility Tank Car and Tank Truck Loading/Unloading Rack: §112.7(h)

- (h) Facility tank car and tank truck loading/unloading rack (excluding offshore facilities).
- (1) Where loading/unloading area drainage does not flow into a catchment basin or treatment facility designed to handle discharges, use a quick drainage system for tank car or tank truck loading and unloading areas. You must design any containment system to hold at least the maximum capacity of any single compartment of a tank car or tank truck loaded or unloaded at the facility.
- (2) Provide an interlocked warning light or physical barrier system, warning signs, wheel chocks, or vehicle break interlock system in loading/unloading areas to prevent vehicles from departing before complete disconnection of flexible or fixed oil transfer lines.
- (3) Prior to filling and departure of any tank car or tank truck, closely inspect for discharges the lowermost drain and all outlets of such vehicles, and if necessary, ensure that they are tightened, adjusted, or replaced to prevent liquid discharge while in transit.

The only loading/unloading rack at the airport is Landmark's Fuel Farm. The area where the trucks park to load or unload the fuel does not have curbing but the area slopes back to the secondary containment for the ASTs. If a spill occurred it would initially flow toward the AST secondary containment and into this containment. The secondary containment for the fuel farm is below grade approximately 21 inches. If a major spill was to occur it would flow to a storm drain, located to the northwest. Within the storm drain there is a catch basin where the spilled material can accumulate and then be removed. The storm drain has two valves to close the drain so the material spilled would not be released to the Vermilion River.

The Landmark Fuel Farm requires trucks to use wheel chocks to prevent the vehicles from departing before the transfer lines are disconnected. Vehicles are also inspected for discharges prior to the vehicle leaving these areas. The Fuel Farm uses a checklist to document inspections. The completed checklists are maintained by Landmark.

#### 4.20 Brittle Fracture Analysis: §112.7(i)

(i) If a field-constructed aboveground container undergoes a repair, alteration, reconstruction, or a change in service that might affect the risk of a discharge or failure due to brittle fracture or other catastrophe, or has discharged oil or failed due to brittle fracture failure or other catastrophe, evaluate the container for risk of discharge or failure due to brittle fracture or other catastrophe, and as necessary, take appropriate action.

None of the field-constructed aboveground containers have undergone a repair, alteration, reconstruction, or a change in service that might affect the risk of a

9070 28 C-K Associates

discharge or failure due to brittle fracture or other catastrophe, or has discharged oil or failed due to brittle fracture failure or other catastrophe. Should these containers undergo repair, alteration, reconstruction, or a change of service, the container will be evaluated for brittle fracture failure potential and appropriate steps will be taken to minimize such potential.

#### 4.21 Applicable Requirements: §112.7(j)

(j) In addition to the minimal prevention standards listed under this section, include in your Plan a complete discussion of conformance with the applicable requirements and other effective discharge prevention and containment procedures listed in this part or any applicable more stringent State rules, regulations, and guidelines.

In accordance with LAC 33:907 (K), responsible airport personnel and tenants will allow properly authorized representative(s) of LDEQ or USEPA to enter the facility and inspect activity areas according to the following protocol:

- Enter facility activity areas where a discharge source is or might be located or in which monitoring equipment or records required by a permit are kept for inspection or sampling purposes. It is understood that most inspections are unannounced and will be allowed to begin immediately, but in no case will begin later than 30 minutes after the time the regulatory agency inspector presents their credentials and announces the purpose(s) of the inspection. It is understood that a delay in excess of 30 minutes will constitute a violation of the Louisiana Water Pollution Control Regulations and that additional time can be granted if the inspector or administrative authority determines that circumstances warrant such action;
- Have access to and copy any records deemed necessary for the enforcement of the Louisiana Water Pollution Control Regulations. If requested records are not available due to their location in an office that is closed at the time of inspection, the records will be made available as soon as the office is open, but no later than the close of business the next working day;
- Inspect any facility areas, equipment (including monitoring and control equipment), practices, or operations regulated or required under the permit; and
- Sample or monitor for the purposes of ensuring permit compliance, or as otherwise authorized by Act 449 of the 1979 Louisiana Legislature (which established Section 1081 et seq. of Title 30 of the Louisiana Revised

9070 29 C-K Associates

Statues of 1950), any substances or parameters at any location.

When an inspector announces that samples will be collected, the airport will prepare containers for duplicates within 30 minutes. It is understood that if container preparation cannot be accomplished in 30 minutes, the airport waives their right to collect duplicate samples during the event. If the administrative authority requires that sampling proceed immediately, without the additional 30 minutes normally allotted, the inspector will provide the airport with duplicate samples from the event.

The airport will ensure that a representative familiar with the wastewater discharge permit and SPCC Plan will be available either by phone or in person at the airport during all hours of operation. The absence of such on-site personnel familiar with the permit will not be grounds for delaying the initiation of an inspection (except with regard to records contained in offices locked at the time of inspection). Inspectors will be required to abide by all company safety rules.

As deemed necessary, LFT will submit a written request for copies of field notes, drawings, etc., taken by the regulatory agency inspector during an inspection. These copies will be provided after the regulatory agency final inspection report has been completed.

Sections 5 and 9 of this Plan provide further detailed discussions of conformance with the applicable federal and state requirements and other effective discharge prevention used at the airport.

9070 30 C-K Associates

### 4.22 Qualified Oil-Filled Operational Equipment: §112.7(k)

- (k) Qualified Oil-filled Operational Equipment. The owner or operator of a facility with oil-filled operational equipment that meets the qualification criteria in paragraph (k)(1) of this sub-section may choose to implement for this qualified oil-filled operational equipment the alternate requirements as described in paragraph (k)(2) of this sub-section in lieu of general secondary containment required in paragraph (c) of this section.
- (1) Qualification Criteria—Reportable Discharge History: The owner or operator of a facility that has had no single discharge as described in § 112.1(b) from any oil-filled operational equipment exceeding 1,000 U.S. gallons or no two discharges as described in § 112.1(b) from any oil-filled operational equipment each exceeding 42 U.S. gallons within any twelve month period in the three years prior to the SPCC Plan certification date, or since becoming subject to this part if the facility has been in operation for less than three years (other than oil discharges as described in § 112.1(b) that are the result of natural disasters, acts of war or terrorism); and (2) Alternative Requirements to General Secondary Containment. If secondary containment is not provided for qualified oil-filled operational equipment pursuant to paragraph (c) of this section, the owner or operator of a facility with qualified oil-filled operational equipment must: (i) Establish and document the facility procedures for inspections or a monitoring program to detect equipment failure and/or a discharge; and (ii) Unless you have submitted a response plan under § 112.20, provide in your Plan the following: (A) An oil spill contingency plan following the provisions of part 109 of this chapter. (B) A written commitment of manpower, equipment, and materials required to expeditiously control and remove any quantity of oil discharged that may be harmful.

The facility has several generators, air compressors, and pumps that qualify as "oil-filled operational equipment". All of the oil-filled operational equipment at the airport is provided with general secondary containment; therefore, this section is not applicable.

#### 5.0 REQUIREMENTS FOR ONSHORE (NON-PRODUCTION) FACILITIES: §112.8

Section 5 of this Plan presents facility-specific details associated with the requirements for onshore non-production facilities outlined in §112.8.

#### 5.1 General: §112.8(a)

If you are the owner or operator of an onshore facility (excluding a production facility), you must: (a) Meet the general requirements for the Plan listed under §112.7, and the specific discharge prevention and containment procedures listed in this section.

9070 31 C-K Associates

This SPCC Plan conforms with and does not deviate from the requirements of 40 CFR §112.7.

### 5.2 Facility Drainage: §112.8(b)

(b)(1) Restrain drainage from diked storage areas by valves to prevent a discharge into the drainage system or facility effluent treatment system, except where facility systems are designed to control such discharge. You may empty diked areas by pumps or ejectors; however, you must manually activate these pumps or ejectors and must inspect the condition of the accumulation before starting, to ensure no oil will be discharged.

Specific discharge and drainage controls at LFT are discussed in Section 4.7.

(b)(2) Use valves of manual, open-and-closed design, for the drainage of diked areas. You may not use flapper-type drain valves to drain diked areas. If your facility drainage drains directly into a watercourse and not into an on-site wastewater treatment plant, you must inspect and may drain uncontaminated retained stormwater, as provided in paragraphs (c)(3)(ii),(iii),and (iv)of this section.

Containment areas for the fuel farms are equipped with drainage valves that are of a manual, open-and-closed design, and allow for the containment and inspection of contained volumes. The drainage valves for these containment areas are operated under responsible supervision. If there is any indication that the water is not suitable for discharge (i.e., sheen, discoloration, odor, film), oil will be removed from water or the storm water will be collected and disposed of off-site. Specific discharge and drainage controls at LFT are discussed in Section 4.7.

(b)(3) Design facility drainage systems from undiked areas with a potential for a discharge (such as where piping is located outside containment walls or where tank truck discharges may occur outside the loading area) to flow into ponds, lagoons, or catchment basins designed to retain oil or return it to the facility. You must not locate catchment basins in areas subject to periodic flooding.

Drainage from undiked areas flows to one of the following locations: Outfalls 002 through 011. The outfalls are routinely visually monitored for quality as required under the facility's LDEQ LPDES MSGP. In the event of a discharge from an undiked area that may migrate toward any of the ten outfalls, temporary containment devices or structures such as booms or earthen berms can be rapidly deployed or constructed to contain spilled substances and prevent the migration to navigable waters. In addition, LFT's storm water drains are adequately sized to contain a spill and allow for the spill to be vacuumed out of the storm water drain before it leaves the site. Additional discharge and drainage controls at LFT are discussed in Section 4.7.

9070 32 C-K Associates

(b)(4) If facility drainage is not engineered as in paragraph (b)(3) of this section, equip the final discharge of all ditches inside the facility with a diversion system that would, in the event of an uncontrolled discharge, retain oil in the facility.

There are drainage controls implemented at LFT and these are discussed further in Section 4.7.

(b)(5) Where drainage waters are treated in more than one treatment unit and such treatment is continuous, and pump transfer is needed, provide two "lift" pumps and permanently install at least one of the pumps. Whatever techniques you use, you must engineer facility drainage systems to prevent a discharge as described in §112.1(b) in case there is an equipment failure or human error at the facility.

LFT does not treat drainage waters in more than one treatment unit; therefore, no discussion related to §112.8(b)(5) is warranted.

### 5.3 Bulk Storage Containers: §112.8(c)

Containers used for oil storage at LFT that qualify as bulk storage containers are limited to ASTs, totes, and portable 55-gallon drums. Therefore, the following discussion pertaining to the requirements of §112.8(c) is limited to these containers.

(c)(1) Not use a container for the storage of oil unless its material and construction are compatible with the material stored and conditions of storage such as pressure and temperature.

All bulk storage tanks at LFT have been designed in accordance with applicable federal, state, and local regulations. Tanks constructed of welded carbon steel are manufactured in accordance with API 650 design specifications. Tanks constructed of other materials (e.g., plastic, fiberglass) are manufactured in accordance with appropriate design standards.

The tanks, totes, and drums also have protective paint coatings as needed for corrosion protection. Tanks, piping, valves, and other appurtenances are also constructed of materials compatible with the products and associated storage conditions with which they are in contact. Temperature, pressure, concentration, trace contaminants, shelf life, vapor/liquid interfaces, and other characteristics are considered when selecting materials of construction.

9070 33 C-K Associates

(c)(2) Construct all bulk storage container installations (except mobile refuelers and other non-transportation-related tank trucks), so that you provide a secondary means of containment for the entire capacity of the largest single container and sufficient freeboard to contain precipitation. You must ensure that diked areas are sufficiently impervious to contain discharged oil. Dikes, containment curbs, and pits are commonly employed for this purpose. You may also use an alternative system consisting of a drainage trench enclosure that must be arranged so that any discharge will terminate and be safely confined in a facility catchment basin or holding pond.

All of the ASTs, totes, and drums within the airfield either have appropriate secondary containment or are double-walled. Secondary containment for the fuel farm consists of a concrete dike capable of containing the entire contents of the largest tank plus sufficient freeboard for precipitation, as documented in Appendix B-4. Containment areas are sufficiently impervious to contain discharged oil products.

(c)(3) Not allow drainage of uncontaminated rainwater from the diked area into a storm drain or discharge of an effluent into an open watercourse, lake, or pond, bypassing the facility treatment system unless you: (i) Normally keep the bypass valve sealed closed. (ii) Inspect the retained rainwater to ensure that its presence will not cause a discharge as described in §112.1(b). (iii) Open the bypass valve and reseal it following drainage under responsible supervision; and (iv) Keep adequate records of such events, for example, any records required under permits issued in accordance with §§122.41(j)(2) and 122.41(m)(3) of this chapter.

Drain valves in the diked areas remain closed until storm water in each area is inspected. Retained volumes in diked areas are inspected for evidence of oil, such as film, sheen, or discoloration, prior to draining or manual pumping. The drain valve in the containment area for the fuel farm remains closed under normal operating conditions and is only opened under responsible supervision to drain uncontaminated rainwater. Results of visual inspections and the drainage of uncontaminated rainwater are maintained by and filed by the operators of the Landmark and Private Aircraft Hangar Fuel Farms.

(c)(4) Protect any completely buried metallic storage tank installed on or after January 10, 1974 from corrosion by coatings or cathodic protection compatible with local soil conditions. You must regularly leak test such completely buried metallic storage tanks.

LFT has one completely buried fiberglass storage tank located on its property, also known as a UST, within the fenced area. The UST is one 12,000-gallon tank, installed on September 7, 1986, that contains jet fuel. The tank belongs to Frank's Casing. The UST suction product lines are fiberglass and the metal components on the dispenser are booted. The release detection method is an automatic tank gauging. The product line is safe suction. The site has a spill bucket and a

9070 34 C-K Associates

butterfly valve for overfill protection.

Outside of the fenced area but still on LFT's property, Brenton Investments (the Shell gas station) has four USTs. The USTs consist of one 10,000-gallon gasoline UST, two 6,000-gallon gasoline USTs, and one 6,000-gallon diesel UST. The system is a pressurized system with fiberglass lines and low-level detectors (LLDs). The facility UST system has a spill and overfill ball float and butterfly valves. All of the USTs are steel tanks lined for protection. The gasoline USTs were installed in February 1974 and upgraded in November 1998. The diesel UST was installed in February 1988 and upgraded in November 1998. The site has monitor wells to detect any leaks from the USTs. These wells are inspected annually. These tanks have cathodic protection.

(c)(6)Test or inspect each aboveground container for integrity on a regular schedule and whenever you make material repairs. You must determine, in accordance with industry standards, the appropriate qualifications for personnel performing tests and inspections, the frequency and type of testing and inspections, which take into account container size, configuration, and design (such as containers that are: shop-built, field-erected, skid-mounted, elevated, equipped with a liner, double-walled, or partially buried). Examples of these integrity tests include, but are not limited to: visual inspection, hydrostatic testing, radiographic testing, ultrasonic testing, acoustic emissions testing, or other systems of non-destructive testing. You must keep comparison records and you must also inspect the container's supports and foundations. In addition, you must frequently inspect the outside of the container for signs of deterioration, discharges, or accumulation of oil inside diked areas. Records of inspections and tests kept under usual and customary business practices satisfy the recordkeeping requirements of this paragraph.

Tanks are observed by airport personnel during operating hours. Informal visual inspections are informally conducted as daily routine duties. Visual external inspections of all LAC-owned ASTs, associated piping and appurtenances, and containers are recommended as a good engineering practice to be conducted monthly at LFT. The formal tank in-service inspection will be conducted annually at LFT. Under SP001 integrity testing will be conducted as appropriate for ASTs where visual inspections indicate issues at LFT. These inspections are documented using the inspection forms found in Appendix F. When necessary, based on visual inspection or monitoring results, tanks are drained, cleaned, inspected, repaired, and/or painted.

(c)(7) Control leakage through defective internal heating coils by monitoring the steam return and exhaust lines for contamination from internal heating coils that discharge into an open watercourse, or pass the steam return or exhaust lines through a settling tank, skimmer, or other separation or retention system.

There are no internal heating coils at LFT; therefore, the requirements of

9070 35 C-K Associates

112.8(c)(7) do not apply.

(c)(8) Engineer or update each container installation in accordance with good engineering practice to avoid discharges. You must provide at least one of the following devices: (i) High liquid level alarms with an audible or visual signal at a constantly attended operation or surveillance station. In smaller facilities an audible air vent may suffice. (ii) High liquid level pump cutoff devices set to stop flow at a predetermined container content level. (iii) Direct audible or code signal communication between the container gauger and the pumping station. (iv) A fast response system for determining the liquid level of each bulk storage container such as digital computers, telepulse, or direct vision gauges. If you use this alternative, a person must be present to monitor gauges and the overall filling of bulk storage containers. (v) You must regularly test liquid level sensing devices to ensure proper operation.

The fuel farm tanks are equipped with emergency shut-off valves. Gauges on the tanks are monitored for proper operation during tank loading operations and during formal inspections of the tanks. These gauges are in place to assist in preventing overfilling. Some tanks have level controls, while others are gauged manually.

(c)(9) Observe effluent treatment facilities frequently enough to detect possible system upsets that could cause a discharge as described in §112.1(b).

Under normal airport operations, storm water and wash water from the six wash racks are the only effluent that is discharged from the airport. Currently, LFT has an LDEQ LPDES MSGP and follows the parameters and requirements identified in that permit to ensure that the effluent limits are not exceeded.

LFT operates six wash racks, which are described below and shown on Figure 2. These six wash racks are covered by LDEQ's General Permit for Exterior Vehicle Wash Wastewater (No. LAG750655).

- Outfall 001A is Landmark Wash Rack #1 and is located west of Landmark's building. This rack is used to wash aircraft and vehicles. This outfall eventually drains to Outfall 002.
- Outfall 001B is Landmark Wash Rack #2 and is located between Landmark's hangars #10 and #11. This rack is used to wash aircraft and vehicles. This outfall eventually drains to Outfall 011.
- Outfall 001C is located near Acadian Ambulance hangar and is used to wash vehicles and helicopters. This outfall eventually drains to Outfall 011.

9070 36 C-K Associates

- Outfall 001D is located east of the LFT Maintenance Shop and is used to wash vehicles and equipment. This outfall eventually drains to Outfall 002.
- Outfall 001E is located next to the ARFFD building and is utilized to wash vehicles. The outfall eventually drains to Outfall 011.
- Outfall 001F is located next to Gate 7 and is utilized to wash aircraft, helicopters, and vehicles. The outfall eventually drains to Outfall 011.

(c)(10) Promptly correct visible discharges which result in a loss of oil from the container, including but not limited to seams, gaskets, piping, pumps, valves, rivets, and bolts. You must promptly remove any accumulations of oil in diked areas.

Visible oil leaks are reported upon observation so they can be repaired immediately. Measures are taken to minimize and mitigate any observed leaks. Any oil spill is cleaned up immediately by appropriate personnel.

(c)(11) Position or locate mobile or portable oil storage containers to prevent a discharge as described in §112.1(b). Except for mobile refuelers and other non-transportation-related tank trucks, you must furnish a secondary means of containment, such as a dike or catchment basin, sufficient to contain the capacity of the largest single compartment or container with sufficient freeboard to contain precipitation.

Drums and smaller containers are stored on portable containment pallets, racks, or in flammable cabinets throughout the airport. Most of the drum storage areas are roofed to exclude precipitation. Sufficient volume is available within curbed areas to contain the capacity of the largest single container. Inside LFT's fenced area, the FBO has four mobile refueling trucks used to fuel planes and helicopters.

#### 5.4 Facility Transfer Operations, Pumping, and Facility Process: §112.8(d)

(d)(1) Provide buried piping that is installed or replaced on or after August 16, 2002, with a protective wrapping and coating. You must also cathodically protect such buried piping installations or otherwise satisfy the corrosion protection standards for piping in part 280 of this chapter or a State program approved under part 281 of this chapter. If a section of buried line is exposed for any reason, you must carefully inspect it for deterioration. If you find corrosion damage, you must undertake additional examination and corrective action as indicated by the magnitude of the damage.

The current buried piping system was installed prior to August 16, 2002. Future installations or replacements of buried piping will be provided with protective wrapping and coating, as appropriate, according to pipe material and construction.

9070 37 C-K Associates

Cathodic protection or other corrosion protection will be provided in accordance with 40 CFR Part 280 or applicable state programs approved under 40 CFR Part 281. Exposed lines will be carefully inspected for deterioration. If corrosion damage is observed, additional examination and corrective action is taken, as appropriate.

(d)(2)Cap or blank-flange the terminal connection at the transfer point and mark it as to origin when piping is not in service or is in standby service for an extended time.

At the time this Plan was prepared, there were no pipelines at the facility that are out of service or in standby service. If piping is placed out of service or on standby service, the facility connections of transfer points will be capped or blank-flanged, and LFT will ensure that the origin points on these transfer points are marked when they are not in use.

(d)(3)Properly design pipe supports to minimize abrasion and corrosion and allow for expansion and contraction.

Pipe supports for aboveground pipelines are designed to minimize abrasion and corrosion and to allow for expansion and contraction.

(d)(4) Regularly inspect all aboveground valves, piping, and appurtenances. During the inspection you must assess the general condition of items, such as flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces. You must also conduct integrity and leak testing of buried piping at the time of installation, modification, construction, relocation, or replacement.

Aboveground valves, pipe supports, pipes, and pipelines are inspected on a regular basis. Informal daily visual inspections are conducted from the ground during normal routine airport rounds. Formal visual inspections of piping associated with ASTs are conducted and documented on an annual basis. The formal tank in-service inspection will be conducted annually at LFT. Integrity testing will be conducted every 5 to 7 years at LFT by the appropriate party (i.e., the tenant or FBOs). When buried piping is modified, relocated, or replaced, or when new buried piping is installed or constructed, integrity and leak testing of those pipes will be conducted.

(d)(5) Warn all vehicles entering the facility to be sure that no vehicle will endanger above ground piping or other oil transfer operations.

There are signs posted wherever trucks are loading or unloading regarding the proper procedures. There are railings and barricades in place to protect aboveground piping, equipment, and tanks from damage from vehicular traffic.

9070 38 C-K Associates

Proper procedures for fueling and defueling aircraft are found in the LFT Certification Manual, Section VII – Hazardous Materials, which was approved by the Federal Aviation Administration on May 24, 2005.

### 6.0 REQUIREMENTS FOR ONSHORE OIL PRODUCTION FACILITIES: §112.9

LFT is not an onshore oil production facility. Consequently, the provisions in §112.9 do not apply.

### 7.0 REQUIREMENTS FOR ONSHORE OIL DRILLING AND WORKOVER FACILITIES: §112.10

LFT is not an onshore oil drilling or workover facility. Consequently, the provisions in §112.10 do not apply.

### 8.0 REQUIREMENTS FOR OFFSHORE OIL DRILLING, PRODUCTION, AND WORKOVER FACILITIES: §112.11

LFT is not an offshore oil drilling, production, or workover facility. Consequently, the provisions in §112.11 do not apply.

## 9.0 REQUIREMENTS FOR ANIMAL FATS AND OILS AND GREASES, AND FISH AND MARINE MAMMAL OILS; AND FOR VEGETABLE OILS, INCLUDING OILS FROM SEEDS, NUTS, FRUITS, AND KERNELS: §112.12

Section 9.0 of this Plan presents the facility-specific details associated with the requirements for edible oils as outlined in §112.12. It should be noted that all edible oil bulk storage containers are owned by tenants and not the airport.

#### 9.1 General: §112.12

If you are the owner or operator of an onshore facility (excluding a production facility), you must: (a) Meet the general requirements for the Plan listed under §112.7, and the specific discharge prevention and containment procedures listed in this section.

This SPCC Plan comforms with and does not deviate from the requirements of 40 CFR §112.12 except as noted.

9070 39 C-K Associates

### 9.2 Facility Drainage

(b)(1) Restrain drainage from diked storage areas by valves to prevent a discharge into the drainage system or facility effluent treatment system, except where facility systems are designed to control such discharge. You may empty diked areas by pumps or ejectors; however, you must manually activate these pumps or ejectors and must inspect the condition of the accumulation before starting, to ensure no oil will be discharged.

(b)(2) Use valves of manual, open-and-closed design, for the drainage of diked areas. You may not use flapper-type drain valves to drain diked areas. If your facility drainage drains directly into a watercourse and not into an on-site wastewater treatment facility, you must inspect and may drain uncontaminated retained storm water, as provided in paragraphs (c)(3)(ii), (iii), and (iv) of this section.

Facility drainage is designed in a manner that drainage from undiked areas subject to spills, flow to drainage ditches throughout the property. The storm water drainage system is a concrete collection drainage ditch and retention pits. Diked storage areas where there is a reasonable possibility of a discharge will remain closed except when draining uncontaminated rain water.

The facility drainage system is adequately designed to prevent a discharge in case there is an equipment failure or human error in operation.

(b)(3) Design facility drainage systems from undiked areas with a potential for a discharge (such as where piping is located outside containment walls or where tank truck discharges may occur outside the loading area) to flow into ponds, lagoons, or catchment basins designed to retain oil or return it to the facility. You must not locate catchment basins in areas subject to periodic flooding.

The facility drainage system is adequately designed to prevent a discharge in case there is an equipment failure or human error in operation. The grease and used cooking oil storage containers are within areas with general secondary containment, so drainage potential is minimal.

(b)(4) If facility drainage is not engineered as in paragraph (b)(3) of this section, equip the final discharge of all ditches inside the facility with a diversion system that would, in the event of an uncontrolled discharge, retain oil in the facility.

9070 40 C-K Associates

Diked storage areas where there is a reasonable possibility of a discharge will remain closed except when draining uncontaminated rain water. Good housekeeping and BMPs are in place to help control any discharge of materials.

(b)(5) Where drainage waters are treated in more than one treatment unit and such treatment is continuous, and pump transfer is needed, provide two 'lift' pumps and permanently install at least one of the pumps. Whatever techniques you use, you must engineer facility drainage systems to prevent a discharge as described in §112.1(b) in case there is an equipment failure or human error at the facility.

Drainage is not routed to a treatment system at LFT; therefore this requirement is not applicable.

### 9.3 Bulk Storage Containers

(c)(1) Not use a container for the storage of oil unless its material and construction are compatible with the material stored and conditions of storage such as pressure and temperature.

All construction materials for grease and used cooking oil bulk storage tanks, associated piping and valves, and other appurtenances are compatible with stored products. Temperature, pressure, concentration, trace contaminants, shelf life, vapor/liquid interfaces, and other characteristics are considered when selecting materials of construction.

(c)(2) Construct all bulk storage container installations so that you provide a secondary means of containment for the entire capacity of the largest single container and sufficient freeboard to contain precipitation. You must ensure that diked areas are sufficiently impervious to contain discharged oil. Dikes, containment curbs, and pits are commonly employed for this purpose. You may also use an alternative system consisting of a drainage trench enclosure that must be arranged so that any discharge will terminate and be safely confined in a facility catchment basin or holding pond.

The grease and used cooking oil bulk storage containers are not located within sized secondary containment.

9070 41 C-K Associates

(c)(3) Not allow drainage of uncontaminated rainwater from the diked area into a storm drain or discharge of an effluent into an open watercourse, lake, or pond, bypassing the facility treatment system unless you: (i) Normally keep the bypass valve sealed closed. (ii) Inspect the retained rainwater to ensure that its presence will not cause a discharge as described in  $\S112.1(b)$ . (iii) Open the bypass valve and reseal it following drainage under responsible supervision; and (iv) Keep adequate records of such events, for example, any records required under permits issued in accordance with  $\S\S122.41(j)(2)$  and 122.41(m)(3) of this chapter.

The grease and used cooking oil bulk storage containers are not located within sized secondary containment.

(c)(4) Protect any completely buried metallic storage tank installed on or after January 10, 1974 from corrosion by coatings or cathodic protection compatible with local soil conditions. You must regularly leak test such completely buried metallic storage tanks.

LFT has no buried metal storage tanks that are subject to 40 CFR 112; therefore, the requirements of [40 CFR 112.8(c)(4)] do not apply.

(c)(5) Not use partially buried or bunkered metallic tanks for the storage of oil, unless you protect the buried section of the tank from corrosion. You must protect partially buried and bunkered tanks from corrosion by coatings or cathodic protection compatible with local soil conditions.

LFT does not operate any underground fuel storage tanks for edible oils; therefore, the requirements of [40 CFR112.8(c)(5)] do not apply.

(c)(6) Test each aboveground container for integrity on a regular schedule, and whenever you make material repairs. The frequency of and type of testing must take into account container size and design (such as floating roof, skid-mounted, elevated, or partially buried). You must combine visual inspection with another testing technique such as hydrostatic testing, radiographic testing, ultrasonic testing, acoustic emissions testing, or another system of non-destructive shell testing. You must keep comparison records and you must also inspect the container's supports and foundations. In addition, you must frequently inspect the outside of the container for signs of deterioration, discharges, or accumulation of oil inside diked areas. Records of inspections and tests kept under usual and customary business practices will suffice for purposes of this paragraph.

9070 42 C-K Associates

Each edible oil bulk storage container should be inspected on a regular schedule. Inspections are discussed in Section 5.3. For steel containers 5,000 gallon capacity or less with a continuous release detection (e.g., concrete foundation), monthly visual inspection of bulk storage containers is sufficient. Integrity testing may consist of visual inspection, hydrostatic testing, ultrasonic thickness testing, and/or equivalent integrity testing method by a qualified individual and will address tank supports, foundations, piping and valves.

Records are maintained for a period of not less than three years.

(c)(7) Control leakage through defective internal heating coils by monitoring the steam return and exhaust lines for contamination from internal heating coils that discharge into an open watercourse, or pass the steam return or exhaust lines through a settling tank, skimmer, or other separation or retention system.

There are no internal heating coils associated with aboveground tanks at LFT; therefore, the requirements of [40 CFR 112.8(c)(7)] do not apply.

(c)(8) Engineer or update each container installation in accordance with good engineering practice to avoid discharges. You must provide at least one of the following devices: (i) High liquid level alarms with an audible or visual signal at a constantly attended operation or surveillance station. In smaller facilities an audible air vent may suffice. (ii) High liquid level pump cutoff devices set to stop flow at a predetermined container content level. (iii) Direct audible or code signal communication between the container gauger and the pumping station. (iv) A fast response system for determining the liquid level of each bulk storage container such as digital computers, telepulse, or direct vision gauges. If you use this alternative, a person must be present to monitor gauges and the overall filling of bulk storage containers. (v) You must regularly test liquid level sensing devices to ensure proper operation.

All edible oil aboveground storage tanks are filled and/or emptied during active communication with the pumper filling the container.

(c)(9) Observe effluent treatment facilities frequently enough to detect possible system upsets that could cause a discharge as described in §112.1(b).

This section does not apply because LFT does not have a treatment facility on site.

9070 43 C-K Associates

(c)(10) Promptly correct visible discharges which result in a loss of oil from the container, including but not limited to seams, gaskets, piping, pumps, valves, rivets, and bolts. You must promptly remove any accumulations of oil in diked areas.

Visible oil, oil product, or other regulated substance discharges are reported upon observation so they can be controlled and immediately corrected. Measures are taken to minimize and mitigate the spill or leak, and the source of the discharge is repaired or otherwise corrected. Accumulations of oil are promptly removed by responding personnel.

(c)(11) Position or locate mobile or portable oil storage containers to prevent a discharge as described in §112.1(b). Except for mobile refuelers, you must furnish a secondary means of containment, such as a dike or catchment basin, sufficient to contain the capacity of the largest single compartment or container with sufficient freeboard to contain precipitation.

Portable edible oil bulk storage containers at LFT are not furnished with sized secondary containment.

#### 9.4 Facility Transfer Opertions, Pumping, and Facility Process: §112.8(d)

(d)(1) Provide buried piping that is installed or replaced on or after August 16, 2002, with a protective wrapping and coating. You must also cathodically protect such buried piping installations or otherwise satisfy the corrosion protection standards for piping in part 280 of this chapter or a State program approved under part 281 of this chapter. If a section of buried line is exposed for any reason, you must carefully inspect it for deterioration. If you find corrosion damage, you must undertake additional examination and corrective action as indicated by the magnitude of the damage.

There is no buried piping associated with edible oil bulk storage containers. Should future installations of buried piping be necessary, the buried piping will be provided with protective wrapping and coating, as appropriate, according to pipe material and construction. Cathodic protection or other corrosion protection will be provided in accordance with 40 CFR Part 280 or applicable state programs approved under 40 CFR Part 281. Exposed lines will be carefully inspected for deterioration. If corrosion damage is observed, additional examination and corrective action is taken, as appropriate.

9070 44 C-K Associates

(d)(2) Cap or blank-flange the terminal connection at the transfer point and mark it as to origin when piping is not in service or is in standby service for an extended time..

Future pipelines (if constructed) will be capped or blank-flanged at terminal connections at the transfer point and are marked to indicate flow origin if the piping is out of service or in standby service for an extended time.

(d)(3) Properly design pipe supports to minimize abraision and corrosion and allow for expansion and contraction.

Future pipe supports (if constructed) for aboveground pipelines will be properly designed to minimize abrasion and corrosion and to allow for expansion and contraction.

(d)(4) Regularly inspect all aboveground valves, piping, and appurtenances. During the inspection you mus assess the general condition of items, such as flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces. You must also conduct integrity and leak testing of buried piping at the time of installation, modification, construction, relocation, or replacement.

Future aboveground valves, pipe supports, pipes, and pipelines (if constructed) will be inspected on a quarterly basis in accordance with the procedure provided in Apendix F. Routine inspections are visual, external, conducted from the ground, and conducted simultaneously with other container inspections.

(d)(5) Warn all vehicles entering the facility to be sure that no vehicle will endanger aboveground piping or other oil transfer operations.

Future aboveground piping and terminal connections (if constructed) will be clearly visible and protected from vehicular traffic.

9070 45 C-K Associates





### TABLE 1 Regulatory Cross-Reference Comparison


SPCC	C Plan E	lements	USEPA's Oil Pollution Prevention Regulation	LDEQ's Oil Pollution Prevention Regulation
			(40 CFR Part 112)	(LAC 33:Part IX.Chapter 9)
i	Manag	gement Approval	§112.7(d)	§907(E)
ii		eering Certification	§112.3(d)	
1.0	Introd	uction		
2.0	Genera	al Applicability	§112.1	§903
3.0		Plan Administration	§112.3, §112.4, §112.5,	§905
			§112.6	
	3.1	Requirement to Prepare	§112.3	
	3.2	Amendment by Regional or State Administrator	§112.4	
	3.3	SPCC Plan Amendment by Owner/Operator	§112.5	
	3.4	Qualified Facility Plan Requirements	§112.6	
4.0		Plan General Requirements	§112.7	§907
	4.1	General Facility Information		907(B)
	4.2	General Facility Description		907(B)
	4.3	SPCC Plan Conformance and Deviations	§112.7(a)(1) and (2)	§907(A)
	4.4	Facility Layout	§112.7(a)(3)	§907(B)
	4.5	Oil Storage Capacity	§112.7(a)(3)(i)	§907(B), 907(C)
	4.6	Discharge Prevention Measures	§112.7(a)(3)(ii)	§907(D), 907(F)(9)
	4.7	Discharge or Drainage Controls	§112.7(a)(3)(iii)	§907(D), 907(G)
	4.8	Countermeasures for Discharge Discovery,	§112.7(a)(3)(iv)	§907(B), 907(D)
		Response, and Cleanup		
	4.9	Recovered Materials Disposal	§112.7(a)(3)(v)	§907(B)
	4.10	Contact List and Notification Phone Numbers	§112.7(a)(3)(vi)	§907(B)
	4.11	Reporting and Notification Procedures	§112.7(a)(4)	§907(D)
	4.12	Oil Spill Response Procedures	§112.7(a)(5)	§907(B)
	4.13	Discharge Analysis	§112.7(b)	§907(C)
	4.14	Spill Containment	§112.7(c)	§907(D, §907(F)(1-3)
	4.15	Spill Containment Practicability	§112.7(d)	§907(E)
	4.16	Inspections, Tests, and Records	§112.7(e)	§907(F), §907(F)(8), §907(J)
	4.17	Personnel Training and Discharge Prevention Procedures	§112.7(f)	§907(I)
	4.18	Security	§112.7(g)	§907(H)
	4.19	Facility Railcar and tank Truck Loading/Unloading Rack	§112.7(h)	§907(F)(9-11)
	4.20	Brittle Fracture Analysis	§112.7(i)	
	4.21	Applicable Requirements	§112.7(j)	§907(K)
	4.22	Qualified Oil-Filled Operational Equipment	§112.7(k)	87 - 1 ()
5.0		rements for Onshore (Non-Production) Facilities	§112.7(k)	
2.0	5.1	General	§112.8(a)	<u> </u>
	5.2	Facility Drainage	§112.8(b)	§907(F)(2), §907(G)
	5.3	Bulk Storage Containers	§112.8(c)	\$907(F)(1-4)
	5.4	Facility Transfer Operations, Pumping, and Facility	§112.8(d)	\$907(F)(5-11)
	<u>L</u>	Process		
6.0	Requi	rements for Onshore Oil Production Facilities	§112.9	
7.0		rements for Onshore Drilling and Workover Facilities	§112.10	
8.0		rements for Offshore Oil Drilling, Production, and over Facilities	§112.11	
9.0	Requir Fish a	rements for Animal Fats and Oils and Greases, and and Marine, Mammal Oils, and for Vegetable Oils, ing Oils from Seeds, Nuts, Fruits, and Kernels	§112.12	
	9.1	General	§112.8(a)	

### TABLE 1 Regulatory Cross-Reference Comparison

SPC	C Plan E	Elements	USEPA's Oil Pollution	LDEQ's Oil Pollution Prevention				
			Prevention Regulation	Regulation				
			(40 CFR Part 112)	(LAC 33:Part IX.Chapter 9)				
	9.2	Facility Drainage	§112.8(b)					
	9.3	Bulk Storage Containers	§112.8(c)					
	9.4	Facility Transfer Operations, Pumping, and Facility	§112.8(d)					
		Process						









## APPENDIX A SUBSTANTIAL HARM CHECKLIST

### APPENDIX A Applicability of Substantial Harm Criteria

Does the facility transfer oil over water to or from vessels and does the facility have a total oil storage capacity greater than or equal to 42,000 gallons?
Yes No_X
Does the facility have a total oil storage capacity greater than or equal to 1 million gallons and within any storage area, does the facility lack secondary containment that is sufficiently large to contain the capacity of the largest aboveground oil storage tank plus sufficient freeboard to allow for precipitation?
Yes No_X
Does the facility have a total oil capacity greater than or equal to 1 million gallons and is the facility located at a distance (as calculated using the appropriate formula in 40 CFR 112, Appendix C or a comparable formula) such that a discharge from the facility could cause injury to fish and wildlife and sensitive environments?
Yes No_X
Does the facility have a total oil storage capacity greater than or equal to 1 million gallons and is the facility located at a distance (as calculated using the appropriate formula in 40 CFR 12, Appendix C or a comparable formula) such that a discharge from the facility would shut down a public drinking water intake?
Yes No_X
Does the facility have a total oil storage capacity greater than or equal to 1 million gallons and has the facility experienced a reportable oil spill in an amount greater than or equal to 10,000 gallons within the last 5 years?
Yes No_X
Certification
I certify under penalty of law that I have personally examined an am familiar with the information submitted in this document, and that based on my inquiry of those individuals responsible for obtaining information, I believe that the submitted information is true, accurate, and complete.  Signature:  Date: 1/2/14  Name (Please type or print): Gregory M. Roberts, A.A.E.
Title: Director of Aviation

## APPENDIX B-1 SPILL HISTORY

Date of Release	Substance Released	Quantity Released	Cause	Area	Tenant Responsible	Actions Taken
9/24/2004	Jet A Fuel	100 gallons	A Planet Air Boeing 727 leaked fuel from the fuel vents	Impacted Storm drains	Responsible	Lafayette HAZMAT, LDEQ, and B&B Cleaners were all contacted. Oil pigs and absorbent booms were placed in the drains, drains were covered, outfalls were
						checked, and Lafayette HAZMAT vacuumed out the storm drain to recover the fuel.
9/15/2006	Oil	100 gallons	Ruptured oil line on a Cessna	Concrete		ARFFD applied Micro Blaze to facilitate cleanup.
12/6/2006	Jet A Fuel	2 gallons	Overfilled plane tank, fuel leaked through vent	Concrete		ARFFD applied Micro Blaze to facilitate cleanup.
3/28/2007	Jet A Fuel	5 gallons	Truck's overflow safety valve failed	Concrete		ARFFD applied Micro Blaze to facilitate cleanup.
6/5/2007	Gasoline	15 gallons	The ball valve failed on the supply line	Concrete		Absorbent pads were placed to stop the flow and ARFFD applied Micro Blaze to facilitate cleanup.
6/8/2007	Oil	11 gallons	Overfilled plan tank, fuel leaked through vent	Concrete		Absorbent pads were placed to stop the flow and ARFFD applied Micro Blaze to facilitate cleanup.
6/10/2007	Oil	1 gallon	Unknown	Concrete		ARFFD applied Micro Blaze to facilitate cleanup.
6/22/2007	Jet A Fuel	7 gallons	Opened connection under pressure	Concrete		Absorbent pads were placed to stop the flow and ARFFD applied Micro Blaze to facilitate cleanup.
6/29/2007	Oil	1 gallon	Unknown	Concrete		ARFFD applied Micro Blaze to facilitate cleanup.
9/17/2007	Glycol	170 gallons	Broken valve on container	Concrete		Material evaporated before reaching the storm drains.
7/2/2008	Used oil	5-10 gallons	Unknown	Dry storm drain		ARFFD removed oil impacted media from drain and applied Micro Blaze to facilitate cleanup.
7/30/2008	AV Gas	10-12 gallons	During filling of AV Gas truck	Concrete		ARFFD applied Micro Blaze to facilitate cleanup.
8/18/2008	Jet A Fuel	5-10 gallons	Blown gasket on fuel truck	Concrete		Spill response measures were immediately deployed by ARFFD
9/17/2008	Fuel	3-5 gallons	Over fueled aircraft	Concrete		ARFFD applied absorbent pads to the free fuel and then applied Micro Blaze to facilitate cleanup.

12/15/2008   Diesel   Unknown   Dumping   Soil   The impacted soil was removed and properly disposed by Odyssey on 1/16/2009.	Date of Release	Substance Released	Quantity Released	Cause	Area Impacted	Tenant Responsible	Actions Taken
disposed by Odyssey on 1716/2009   1909/2009/2009   1909/2009/2009   1909/2009/2009/2009/2009/2009/2009/2009/	12/15/2008	Diesel	Unknown	Dumping			The impacted soil was
2/9/2009							
2/9/2009							disposed by Odyssey on
Pads and vermiculite to facilitate cleanup.							1/16/2009.
2/28/2009   Hydraulic fluid   1 gallon   Equipment   Soil   Soil was removed and properly disposed.	2/9/2009	Hydraulic fluid	1 gallon	Equipment	Concrete		Continual use of absorbent
2/28/2009   Hydraulic fluid   1 gallon   Equipment leak   Soil   Soil was removed and properly disposed.				leak			
Property disposed   1 gallon   Overfilled   Concrete							I
A/24/2009   Diesel   I gallon   Overfilled cquipment   Concrete   ARFFD applied Micro Blaze to facilitate cleanup.	2/28/2009	Hydraulic fluid	1 gallon	Equipment	Soil		Soil was removed and
equipment pads to the free fuel and then applied Micro Blaze to facilitate cleanup.  4/24/2009 Hydraulic fluid 1/4 gallon Aircraft leak Concrete ARFFD applied Vermiculite to facilitate cleanup.  6/5/2009 Gasoline 1 gallon Overfilled Concrete tank to facilitate cleanup.  6/10/2009 Gasoline 1 gallon Overfilled Concrete tank Concrete tank TAFFD applied Micro Blaze to facilitate cleanup.  7/14/2009 Jet A fuel 2 gallons Mower cut fuel hose fuel hose fuel has been fuel hose fuel has been fuel hose aircraft pads to facilitate cleanup.  7/17/2009 Avgas 1/4 gallon Overfilled Concrete ARFFD applied Micro Blaze to facilitate cleanup.  7/21/2009 Diesel/Gasoline 1 gallon Improper tank Concrete ARFFD applied Micro Blaze to facilitate cleanup.  8/10/2009 Avgas 1 gallon Leaking fitting on fuel tanker and tanker tanker and tanker to facilitate cleanup.  8/11/2009 Gasoline 1 gallon Overfilled Concrete ARFFD applied Micro Blaze to facilitate cleanup.  8/11/2009 Gasoline 1 gallon Overfilled Concrete ARFFD applied Micro Blaze to facilitate cleanup.  9/1/2009 Gasoline 1 cup Leaking concrete fedix stopped the leak and cleaned up.  9/1/2009 Gasoline 1 cup Loose fitting Concrete Fedix stopped the leak and cleaned up.  9/1/2009 Gasoline 1 cup Loose fitting Concrete for facilitate cleanup.  10/9/2009 Avgas 1/4 gallon Leak during Concrete ARFFD applied Micro Blaze to facilitate cleanup.  10/9/2009 Oil 3 gallons Broken hydraulic line fuel in gallon beautiful fuel fuel facilitate cleanup. ARFFD applied Micro Blaze to facilitate cleanup. AsfFD applied Micro Blaze to facilitate cleanup. FedEx applied Micro Bla							
Applied Micro Blaze to facilitate cleanup.	4/24/2009	Diesel	1 gallon		Concrete		* *
4/24/2009   Hydraulic fluid   ¼ gallon   Aircraft leak   Concrete   ARFFD applied vermiculite to facilitate cleanup.				equipment			
4/24/2009   Hydraulic fluid   ¼ gallon   Aircraft leak   Concrete   ARFFD applied vermiculite to facilitate cleanup.							
G/5/2009   Gasoline   1 gallon   Overfilled   Concrete   ARFFD applied Micro Blaze to facilitate cleanup.							
G/S/2009   Gasoline   1 gallon   Overfilled   Concrete   tank   tank   tank   Concrete   ARFFD applied Micro Blaze to facilitate cleanup.	4/24/2009	Hydraulic fluid	⅓ gallon	Aircraft leak	Concrete		
Concrete							
Gasoline   1 gallon   Overfilled   Concrete   ARFFD applied Micro Blaze to facilitate cleanup.	6/5/2009	Gasoline	1 gallon		Concrete		
Tol.							
Total Price	6/10/2009	Gasoline	1 gallon		Concrete		
Fuel hose   Facilitate cleanup.							
7/17/2009   Avgas   1/4 gallon   Overfilled aircraft   Concrete   ARFFD applied absorbent pads to facilitate cleanup.	7/14/2009	Jet A fuel	2 gallons		Soil		
ArFFD applied Micro Blaze to facilitate cleanup.   B/10/2009   Avgas   1 gallon   Leaking fitting on fuel tanker   Leaking fitting on fuel tanker   S/10/2009   Gasoline   1 gallon   Leaking fitting on fuel tanker   Concrete   ARFFD applied Micro Blaze to facilitate cleanup.							
Ty21/2009   Diesel/Gasoline   1 gallon   Improper tank   Concrete   ARFFD applied Micro Blaze to facilitate cleanup.	7/17/2009	Avgas	⅓ gallon		Concrete		
Section   Sect							
S/10/2009	7/21/2009	Diesel/Gasoline	1 gallon	Improper tank	Concrete		
Saline   Fitting on fuel tanker   Concrete	0 /4 0 /2 0 0 0		4 11				
Second   S	8/10/2009	Avgas	I gallon		Concrete		
Soliticate cleanup.							
S/11/2009   Gasoline   1 gallon   Overfilled tank   Concrete   ARFFD applied Micro Blaze to facilitate cleanup.				tanker			
tank to facilitate cleanup.  9/1/2009 Oil 1 cup Leaking equipment Concrete  9/4/2009 Gasoline 1 cup Loose fitting on tank Concrete  9/15/2009 Avgas 1/4 gallon Leak during fueling  10/9/2009 Oil 3 gallons Broken hydraulic line hydraulic line  10/19/2009 Oil 3 gallons Leaking Concrete and soil FedEx applied Micro Blaze to facilitate cleanup, deployed booms, and MSTC disposed of the soil. LDEQ was contacted.  10/19/2009 Oil 3 gallons Leaking Concrete and hydraulic line storm drain and contained the oil.  11/25/2009 Oil 1/4 gallon Leaking Concrete facilitate cleanup. FedEx applied Micro Blaze to facilitate cleanup.	9/11/2000	Gasalina	1 gallon	Overfilled	Congrete		
9/1/2009   Oil   1 cup   Leaking equipment   Concrete   FedEx stopped the leak and cleaned up.	6/11/2009	Gasonne	i ganon		Concrete		
Poly	0/1/2000	Oil	1 oun		Congrete		
9/4/2009   Gasoline   1 cup   Loose fitting on tank   Concrete on tank   Oncrete o	9/1/2009	Oli	1 cup	_	Concrete		
On tank   On t	9/4/2009	Gasolina	1 cun		Concrete		
9/15/2009   Avgas   1/4 gallon   Leak during fueling   Concrete   ARFFD applied Micro Blaze to facilitate cleanup.	)/ <del>-1</del> /2007	Gasonne	1 cup	_	Concrete		* *
Total fueling   Total fueling   Total fueling   Total facilitate cleanup.	9/15/2009	Avgas	1/4 gallon		Concrete		
10/9/2009   Oil   3 gallons   Broken hydraulic line   Lake water and soil   ARFFD applied Micro Blaze to facilitate cleanup, deployed booms, and MSTC disposed of the soil. LDEQ was contacted.	7/13/2007	111843	74 garion	_	Concrete		
hydraulic line and soil to facilitate cleanup, deployed booms, and MSTC disposed of the soil. LDEQ was contacted.  10/19/2009 Oil 3 gallons Leaking hydraulic line storm drain facilitate cleanup. Absorbent skimmer was located in storm drain and contained the oil.  11/25/2009 Oil 1/4 gallon Leaking equipment facilitate cleanup.  11/25/2009 Oil 3/4 gallon Leaking Concrete FedEx applied Micro Blaze to facilitate cleanup.	10/9/2009	Oil	3 gallons		Lake water		
booms, and MSTC disposed of the soil. LDEQ was contacted.  10/19/2009 Oil 3 gallons Leaking hydraulic line storm drain  11/25/2009 Oil 1/4 gallon Leaking equipment  11/25/2009 Oil 3/4 gallon Leaking Concrete  11/25/2009 Oil 3/4 gallon Leaking Concrete  11/25/2009 FedEx applied Micro Blaze to facilitate cleanup.  11/25/2009 FedEx applied Micro Blaze to facilitate cleanup.  11/25/2009 FedEx applied Micro Blaze to FedEx applied Micro Blaze to FedEx applied Micro Blaze to	10/5/2005	On	3 ganons				
of the soil. LDEQ was contacted.  10/19/2009 Oil 3 gallons Leaking hydraulic line storm drain  11/25/2009 Oil 1/4 gallon Leaking concrete and storm drain  11/25/2009 Oil 1/4 gallon Leaking concrete equipment  Concrete FedEx applied Micro Blaze to facilitate cleanup. FedEx applied Micro Blaze to facilitate cleanup.  FedEx applied Micro Blaze to facilitate cleanup.  FedEx applied Micro Blaze to facilitate cleanup.				11) 01444110 11110	una son		
Contacted.   Concrete and hydraulic line   Concrete and hydraulic line   Storm drain   FedEx applied Micro Blaze to facilitate cleanup. Absorbent skimmer was located in storm drain and contained the oil.							
10/19/2009 Oil 3 gallons Leaking hydraulic line storm drain  11/25/2009 Oil 1/4 gallon Leaking equipment  11/25/2009 Oil 3/4 gallon Leaking Concrete  11/25/2009 Oil 3/4 gallon Leaking Concrete  11/25/2009 FedEx applied Micro Blaze to facilitate cleanup.  11/25/2009 FedEx applied Micro Blaze to facilitate cleanup.  11/25/2009 FedEx applied Micro Blaze to FedEx applied Micro Blaze to FedEx applied Micro Blaze to							
hydraulic line storm drain facilitate cleanup. Absorbent skimmer was located in storm drain and contained the oil.  11/25/2009 Oil 1/4 gallon Leaking Concrete facilitate cleanup.  11/25/2009 Oil 3/4 gallon Leaking Concrete FedEx applied Micro Blaze to facilitate cleanup.  11/25/2009 FedEx applied Micro Blaze to	10/19/2009	Oil	3 gallons	Leaking	Concrete and		
skimmer was located in storm drain and contained the oil.  11/25/2009 Oil 1/4 gallon Leaking Concrete FedEx applied Micro Blaze to equipment facilitate cleanup.  11/25/2009 Oil 3/4 gallon Leaking Concrete FedEx applied Micro Blaze to			<i>G</i>	_			
drain and contained the oil.  11/25/2009 Oil 1/4 gallon Leaking Concrete FedEx applied Micro Blaze to equipment facilitate cleanup.  11/25/2009 Oil 3/4 gallon Leaking Concrete FedEx applied Micro Blaze to							
11/25/2009 Oil ¼ gallon Leaking Concrete FedEx applied Micro Blaze to equipment facilitate cleanup.  11/25/2009 Oil ¾ gallon Leaking Concrete FedEx applied Micro Blaze to							
equipment facilitate cleanup.  11/25/2009 Oil 3/4 gallon Leaking Concrete FedEx applied Micro Blaze to	11/25/2009	Oil	¼ gallon	Leaking	Concrete		
11/25/2009 Oil 3/4 gallon Leaking Concrete FedEx applied Micro Blaze to			<del>-</del>	_			
	11/25/2009	Oil	3⁄4 gallon		Concrete		
			<del>-</del>	_			

Date of Release	Substance Released	Quantity Released	Cause	Area Impacted	Tenant Responsible	Actions Taken
2/11/2010	Diesel	1 gallon	Overflow during fueling	Soil and gravel		The contaminated soil and gravel was excavated and disposed of off-site by FCC
2/26/2010	Handananii a fini d	<1 11	Dalt landan	Community		Environmental.
3/26/2010	Hydraulic fluid	<1 gallon	Belt loader line leaked	Concrete		Absorbent pads and Micro Blaze were applied to facilitate cleanup.
3/30/2010	Skydrol	<1 gallon	Leaking from an aircraft	Asphalt		Absorbent pads were applied to facilitate cleanup.
5/5/2010	Oil	3 gallon	Overfilled oil tank on truck	Concrete	Fedex	Absorbent pads were applied to facilitate cleanup.
5/5/2010	Fuel	2 gallons	Pilot error	Concrete	Odyssey	Absorbent pads and Micro Blaze.
5/25/2010	Diesel	1 gallon	Overfill fuel tanks in heat	Concrete	Odyssey	Absorbent pads and Micro Blaze.
6/1/2010	Oil	¾ quart	Broken hose on aircraft	Asphalt	Franks	Micro Blaze
6/15/2010	Sydrol	½ gallon	Broken nose gear	Concrete	FedEx	Oil dry
6/15/2010	Oil	2 cups	Leaking engine	Asphalt	Odyssey	Oil dry – Micro Blaze
7/27/2010	Jet A	3 gallons	Overfilled aircraft	Concrete	ASA	Micro Blaze/boom
8/2/2010	Diesel	¾ gallon	Overfilled fuel tank	Concrete	Odyssey	Absorbent pads/Micro Blaze
8/20/2010	Oily water	2 gallons	Engine blowout	Concrete	ARFF	Absorbent pads/Micro Blaze
12/14/2010	Jet A	¼ gallon	Leaking fuel truck	Asphalt	Odyssey	Absorbent pads/Micro Blaze
2/7/2011	Glycol	25 gallons	Loose pipe	Concrete & storm drain	Delta	Absorbent pads/Micro Blaze
2/8/2011	Glycol	20 gallons	Broken line	Concrete	AE	Absorbent pads/Micro Blaze/Kitty litter
2/22/2011	Hydraulic	1 gallon	Unknown	Asphalt storm drain	Odyssey	Micro Blaze/Safe drain
2/28/2011	Hydraulic	2 gallons	Broken line	Concrete	FedEx	Micro Blaze/vermiculite
3/3/2011	Glycol	10 gallons	Deicing fluid	Concrete	FedEx	Micro Blaze
3/10/2011	Jet fuel	¼ gallon	Leak during fuel transfer	Concrete	Landmark	Micro Blaze
4/3/2011	Jet fuel	1 gallon	Overfilled tank while fueling	Concrete	PHI	Hazclean
4/14/2011	Hydraulic fluid	½ gallon	Leaking equipment	Concrete	Harper	Vermiculite
5/2/2011	Hydraulic fluid	3 cups	Leaking equipment	Concrete	Delta	Micro Blaze and pads
5/18/2011	Fuel	½ gallon	Fuel truck leak	Concrete and grass	Landmark	Micro Blaze
6/24/2011	Avgas	¼ gallon	Overfilled aircraft	Asphalt	Landmark	Absorbent pads and Micro Blaze
6/25/2011	Hydraulic oil	5 gallons	Overfilled tank	Concrete	FedEx	Vermiculite and Micro Blaze

Date of Release	Substance Released	Quantity Released	Cause	Area Impacted	Tenant Responsible	Actions Taken
8/1/2011	Oil	1 gallon	Leaking equipment	Concrete	Airlines	Micro Blaze
8/3/2011	Oil	½ gallon	Leaking equipment	Concrete	Landmark	Micro Blaze
8/4/2011	Oil	1 gallon	Aircraft leak	Concrete	Unknown	Micro Blaze
8/17/2011	Jet A	1.5 gallons	Unknown	Concrete	Landmark	Micro Blaze
8/30/2011	Jet A	2 quarts	Leaking equipment	Concrete	Landmark	Micro Blaze
11/11/2011	Jet A	12 gallons	Piping installation issue	Concrete	РАН	Micro Blaze
11/11/2011	Jet A	3 gallons	Broken gauge and fuel expansion	Concrete	PAH	Micro Blaze
12/2/2011	Oil	1 gallon	Leaking equipment	Concrete	FedEx	Micro Blaze
1/2/2012	Hydraulic oil	20 gallons	Damaged drum on delivery truck	Concrete	Delivery truck Acadian Ambulance	Absorbent material and Micro Blaze
3/7/2012	Fuel	1 gallon	Unknown	Concrete	Landmark	Micro Blaze
4/9/2012	Jet fuel	1 gallon	Leaking aircraft	Asphalt	Tech school	Absorbent pads and litter
4/26/2012	Hydraulic oil	5 gallons	Leaking equipment	Ground	Drilling company – contractor coastal	Soil removed
4/30/2012	Hydraulic oil	1 gallon	Leaking aircraft	Asphalt	Tech school	Absorbent pads
4/30/2012	Diesel	1 gallon	Overfill tank	Concrete	Landmark	Absorbent and pads Micro Blaze
6/25/2012	Fuel/oil	Unknown	Tank spill	Soil	Maintenance	Soil removed
6/26/2012	Diesel	¼ gallon	Part missing on tank	Concrete	LAC	Boom and Micro Blaze
7/3/2012	Hydraulic	1 ½ gallons	Broken hydraulic line	Concrete	United	United
7/13/2012	Hydraulic	2 gallons	Unknown	Ground	Unknown	Micro Blaze
7/25/2012	Fuel	¼ gallon	Overfilled aircraft	Concrete	Landmark	Absorbent pads
8/7/2012	Fuel	1 ½ gallons	Spill during sumping tank	Asphalt soil	Landmark	Micro Blaze
9/7/2012	Hydraulic	½ gallon	Leaking	Concrete	Delta	Absorbent material
9/6/2012	Fuel	¼ gallon	Unknown	Concrete	Landmark	Micro Blaze
10/3/2012	Hydraulic	2 gallons	Broken line on	Concrete	Express jet	Pads and Micro Blaze
10/12/2012	Hydraulic and coolant	•		Concrete	United	Pads
11/4/2012	Avgas	10 gallons	Aircraft accident	Asphalt	GA Pilot	Micro Blaze

Date	Substance	Quantity	Area	Tenant	Cause	Action Taken
2/27/13	Jet A	1 gallon	Fuel Farm	Landmark	Fueling Spill	Micro Blaze
2/28/13	Fuel	5 gallons	PHI Storage Hangar	PHI	Issues with new aircraft during fueling	Boom plus absorbent pads
3/7/13	Fuel	¼ gallon	Delta Ramp	Delta	Unknown	
4/24/13	Fuel	2 gallons	Fuel Farm	Landmark	Leak	Micro Blaze
4/30/13	Jet A	1 gallon	Fuel Farm	Landmark	Leak	Micro Blaze
6/6/13	Deicing Fluid	¼ gallon	Delta Ramp	Delta	Leak	Absorbent
6/6/13	Fuel	½ gallon	Fuel Farm	Landmark	Unknown	Micro Blaze
7/10/13	Fuel	1 gallon	Fuel Farm	Landmark	Leak	Micro Blaze
7/11/13	Fuel	½ gallon	Fuel Farm	Landmark	Unknown	Micro Blaze
7/31/13	Waste Cooking Oil	1 gallon	West Lot	Restaurant	Unknown	Absorbent

# APPENDIX B-2 MATERIAL INVENTORY

### APPENDIX B-2 Material Inventory Inside Airfield

	SPILL	PREVENTION	, CONTROL	, AND COU	NTERMEASU	JRE PLAN				APPENDI WORKSHE	ET #2	
		MATERIAL II	NVENTORY	(Potential Po	ollutant Sourc	es)		•	ame: Lafayette			
	Material	Name of Tenant	Quantity (Gal) Stored	Type of Container	Containment Type	Age (Years)	Type of Tank (Steel/Plastic)	Testing of Tanks	Is there Emergency Shutoff (Yes or No)	How are Tanks Gauged	Likelihood of Contact with Storm Water (Yes or No)	Past Significant Spills/Leaks (Yes or No)
1	Misc. Soaps, Paints, Solvents oils	Acadian Ambulance	<200 (max)	Small Containers, Aerosol Cans	Flammable Locker	N/A	N/A	N/A	N/A	N/A	No	No
2	Soaps, Degreasers, Oils	Acadian Ambulance	6-8 (max)	Drums	Overpack Drum	N/A	N/A	N/A	N/A	N/A	No	No
3	Used Oil	Acadian Ambulance	275 (max)	Tote	Portable Plastic Container	N/A	N/A	N/A	N/A	N/A	No	No
4	Hydraulic/Lube Oils	Frank's Casing Crew	165 (max)	Drums	Stainless Steel Enclosed Container	N/A	N/A	N/A	N/A	N/A	No	No
5	Used Oil	Frank's Casing Crew	55 (max)	Drum	Stainless Steel Enclosed Container	N/A	N/A	N/A	N/A	N/A	No	No
6	Jet Fuel	Frank's Casing Crew	12,000 (max)	UST	N/A	N/A	N/A	N/A	N/A	N/A	No	No
7	LL AvGas	Landmark-Fuel Farm	15,000 (max)	AST	Concrete Dike	14	Steel	Unknown	Yes	Gauge on tank	No	No
8	Waste Fuel (2)	Landmark-Fuel Farm	500	AST	Concrete Dike	14	Steel	Unknown	Yes	Gauge on tank	No	No
9	Gasoline	Landmark-Fuel Farm	500	AST	Concrete Dike	Unknown	Steel	Unknown	Yes	Stick Gauge	No	No
10	Jet Fuel (4)	Landmark-Fuel Farm	15,000(each)	AST	Concrete Dike	14	Steel	Unknown	Yes	Gauge on tank	No	No
11	Off Road Diesel	Landmark-Fuel Farm	550	AST	Concrete Dike	Unknown	Steel	Unknown	Yes	Stick Gauge	No	No
12	LL AvGas	Landmark-Fuel Farm	12,000 (max) empty	AST	Double- walled	Unknown	Steel	Unknown	Yes	Gauge on tank	No	No

### APPENDIX B-2 Material Inventory Inside Airfield

	SPILL	PREVENTION	, CONTROL	, AND COU	NTERMEASU	JRE PLAN				APPEND: WORKSHE	ET #2	
		MATERIAL IN	NVENTORY	(Potential P	ollutant Sourc	ees)			ame: Lafayette ast Revision: (			
	Material	Name of Tenant	Quantity (Gal) Stored	Type of Container	Containment Type	Age (Years)	Type of Tank (Steel/Plastic)	Testing of Tanks	Is there Emergency Shutoff (Yes or No)	How are Tanks Gauged	Likelihood of Contact with Storm Water (Yes or No)	Past Significant Spills/Leaks (Yes or No)
13	Diesel Fuel (for Emergency Generator)	Federal Aviation Administration	2,000 (max)	AST	Double- walled	12	Steel	Unknown	Unknown	Unknown	No	No
14	Jet Fuel (3)	Landmark	5,000	Mobile Fuelers	N/A	Unknown	Steel	Unknown	Yes	Written Log	No	No
15	LL AvGas	Landmark	1,000	Mobile Fueler	N/A	Unknown	Steel	Unknown	Yes	Written Log	No	No
16	Used Oil	Landmark	500	AST	Metal Tray	Unknown	Steel	Unknown	Yes	Written Log	No	No
17	Oil	Landmark	<110 (max)	Drums	Metal Tray	Unknown	Plastic	N/A	Yes	N/A	No	No
18	Misc. Soaps, Paints, Solvents, Oils, Hydraulic Fluid	Landmark	<330 (max) drums	Drums	Containment Pallet	N/A	N/A	N/A	N/A	N/A	No	No
19	Gasoline	Landmark	100	Mobile Fueler Cart	N/A	2	Steel	Unknown	No	N/A	No	No
20	Diesel	Landmark	100	Mobile Fueler Cart	N/A	2	Steel	Unknown	No	N/A	No	No
21	Used oil (2)	Landmark	55	Drums	Containment Pallet	Unknown	Plastic	No	No	N/A	No	No
22	Diesel Fuel (Vehicle Fueling)	Lafayette Airport Response & Fire Fighting Department	500	AST	Double- walled	Unknown	Steel	No	No	Stick Gauge	No	No
23	Gasoline	Lafayette Airport Response & Fire Fighting Department	500	AST	Double- walled	2	Steel	No	Yes	Stick Gauge	No	No

### APPENDIX B-2 Material Inventory Inside Airfield

	SPILL	PREVENTION	, CONTROL	, AND COU	NTERMEASU	URE PLAN				APPENDI WORKSHE	ET #2	
		MATERIAL II	NVENTORY	(Potential Po	_	Facility Name: Lafayette Regional Airport  Date of Last Revision: October 15, 2013						
	Material	Name of Tenant	Quantity (Gal) Stored	Type of Container	Containment Type	Age (Years)	Type of Tank (Steel/Plastic)	Testing of Tanks	Is there Emergency Shutoff (Yes or No)	How are Tanks Gauged	Likelihood of Contact with Storm Water (Yes or No)	Past Significant Spills/Leaks (Yes or No)
24	Waste Oil	Lafayette Airport Response & Fire Fighting Department	500	AST	Double- walled	34	Steel	No	No	Stick Gauge	No	No
25	LL AvGas	Private Aircraft Hangars of Lafayette	2,000	AST	Concrete Dike	2	Steel	No	Yes	Stick Gauge	No	No
26	Jet Fuel (2)	Private Aircraft Hangars of Lafayette	10,000	AST	Concrete Dike	0	Steel	No	Yes	Stick Gauge	No	No
27	Waste Fuel	Private Aircraft Hangars of Lafayette	275	AST	Concrete Dike	2	Steel	No	Yes	Visual Graduations	No	No
28	Waste Oil	UPS Hangar	900	Drums	Double- walled	Unknown	Steel	Unknown	Yes	Unknown	No	No
29	Used Oil Filters, Oily Rags, Used Oil, Fuel Filters	UPS Hangar	275 (max)	Drums	Portable Plastic Container	N/A	Plastic	N/A	N/A	N/A	No	No
30	Oil	LAC	55	Transformer	Vault Building	Unknown	Steel	Unknown	No	N/A	No	No
31	Jet A	Acadian Ambulance	10,000	AST	Double- walled	Unknown	Steel	No	Yes	Gauge	Yes	No

### APPENDIX B-2 Material Inventory Outside of Airport's Fence

#### **APPENDIX B** SPILL PREVENTION, CONTROL, AND COUNTERMEASURE PLAN **WORKSHEET #2** Facility Name: Lafayette Regional Airport MATERIAL INVENTORY (Potential Pollutant Sources) Date of Last Revision: October 15, 2013 Type of Tank **Testing of** Past Significant Material Name of Quantity Type of **Containment** Is there How are Likelihood of Age (Gal) Stored **Tanks Tanks Contact with** Spills/Leaks **Tenant** Container (Years) (Steel/Plastic) **Emergency** Type Gauged Shutoff **Storm Water** (Yes or No) (Yes or No) (Yes or No) AST Diesel 500 (max) Double-Steel No No Stick Gauge No No Airport 1 Maintenance walled 500 (max) Stick Gauge Gasoline Airport AST Double-1 Steel No No No No Maintenance walled 3 Waste Oil Airport 500 (max) AST 33 No No Stick Gauge No No Double-Steel Maintenance walled N/A Misc. Soaps, <100 (max) Small N/A N/A N/A N/A No No 2-flammable Airport Paints, Oil maintenance Containers, lockers Aerosol Cans 5,000 (max) 5 Yes Stick Gauge No No 5 Gasoline Avis Rent-A-Car AST Concrete Fiberglass yes Dike, wrapped in Doubleconcrete walled 10,000 UST 36 Steel Lined Yes Yes No No 6 Gasoline **Brenton** N/A Inventory Investments-Reconciliation Shell Station UST 36 Gasoline (2) 6,000 N/A Steel Lined Yes Yes No No Brenton Inventory Investments-Reconciliation Shell Station UST N/A 22 Yes Yes No No Diesel Brenton 6,000 Steel Lined Inventory Investments-Reconciliation Shell Station <150 (max) Concrete Unknown Steel N/A N/A N/A No No Misc. Fuels, Oils Marine Survival Drums **Training Center** Dike (2 max) 500 10 Oily Water Marine Survival AST Concrete Unknown Steel Unknown Unknown Unknown No No **Training Center** Dike 250 Diesel Marine Survival No No 11 AST Concrete Unknown Steel Unknown Unknown Unknown **Training Center** Dike Lubricants, Paint, Moss Motors <100 Small Flammable N/A N/A N/A N/A N/A No No Soaps Containers. Locker Aerosol Cans

### APPENDIX B-2 Material Inventory Outside of Airport's Fence


	SPILL 1	PREVENTION	, CONTROL	, AND COU		JRE PLAN				APPENDIX WORKSHEE	CT #2	
		MATERIAL I	NVENTORY	(Potential P	ollutant Sourc	ees)		•	•	Regional Airpottober 15, 2013		
	Material	Name of Tenant	Quantity (Gal) Stored	Type of Container	Containment Type	Age (Years)	Type of Tank (Steel/Plastic)	Testing of Tanks	Is there Emergency Shutoff (Yes or No)	How are Tanks Gauged	Likelihood of Contact with Storm Water (Yes or No)	Past Significant Spills/Leaks (Yes or No)
13	Jet fuel (2)	PHI Heliport	10,000 (each)	AST	Double- walled	Unknown	Carbon Steel	Yes	Yes	Pop-up Gauge & Interstitial Space Gauge	No	No
14	WD-40, Methyl Ethyl Ketone	PHI Heliport	<165 (max)	Drums (3 max)	Spill Containment Pallet	N/A	N/A	N/A	N/A	N/A	No	No
15	Used Oil, Hydraulic Fluid	PHI Heliport	<165 (max)	Drums (3 max)	Spill Containment Pallet	N/A	N/A	N/A	N/A	N/A	No	No
16	Used Oil	PHI Main Facility	500	AST	Double- walled	Unknown	Carbon Steel	Yes	Unknown	N/A	No	No
17	Hazardous Materials (Toluene, Methyl Ethyl Ketone, Thinners, Paint waste)	PHI Main Facility	<660 (max)	Drums (12 max)	Concrete	N/A	N/A	N/A	N/A	N/A	No	No
18	Misc. Fuels, Gasoline	PHI Main Facility	<220 (max)	Drums (4 max)	Concrete	N/A	N/A	N/A	N/A	N/A	No	No
19	Used Oil	PHI Main Facility	<660 (max)	Drums (12 max)	Concrete	N/A	N/A	N/A	N/A	N/A	No	No
20	Jet Fuel	PHI Main Facility	2,000	Mobile Fueler	N/A	Unknown	N/A	Yes	Yes	Written Log	No	No
21	Jet Fuel	PHI Main Facility	1,000	Mobile Fueler	N/A	Unknown	N/A	Yes	Yes	Written Log	No	No
22	Waste Kitchen Grease	PHI Main Facility	300	AST	Spill Containment Pallet	Unknown	Fiberglass	Unknown	No	Unknown	No	No
23	Jet Fuel	PHI Main Facility	500	AST	Concrete	Unknown	Steel	Yes	Yes	Pop-up Gauge & Interstitial Space Gauge	No	No

#### APPENDIX B-2 Material Inventory Outside of Airport's Fence

	SPILL	PREVENTION	, CONTROL	, AND COU	APPENDIX B WORKSHEET #2							
		MATERIAL I	NVENTORY	(Potential P	Facility Name: Lafayette Regional Airport  Date of Last Revision: October 15, 2013							
	Material	Name of Tenant	Quantity (Gal) Stored	Type of Container	Containment Type	Age (Years)	Type of Tank (Steel/Plastic)	Testing of Tanks	Is there Emergency Shutoff (Yes or No)	How are Tanks Gauged	Likelihood of Contact with Storm Water (Yes or No)	Past Significant Spills/Leaks (Yes or No)
24	Jet Fuel	PHI Main Facility	1,000	AST	Double- walled	Unknown	Steel	Yes	Yes	Pop-up Gauge & Interstitial Space Gauge	No	No
25	Diesel	PHI Main Facility	1,000	AST	Double- walled	Unknown	Steel	Yes	Yes	Pop-up Gauge & Interstitial Space Gauge	No	No
26	Used oil	National Guard	1,000	AST	Double- walled/Concr ete Dike	15	Steel	Unknown	Yes	Stick Gauge	No	No
27	Diesel	National Guard	4,500	AST	Double- walled	15	Steel	Unknown	Yes	Stick Gauge	No	No
28	Diesel	National Guard	1,200	Mobile Fueler	N/A	Unknown	N/A	Yes	Yes	Written Log	No	No
29	Hydraulic, Lube Oils, 15W40, Antifreeze	National Guard	<220 (max)	Drums	Spill Containment Pallet	N/A	Plastic	N/A	N/A	N/A	No	No
30	Oil, Antifreeze, Transmission oil	U.S. Navy/Marine Reserves	<275 (max)	Drums (5 max)	Spill Containment Pallet	N/A	Plastic	N/A	N/A	N/A	No	No
31	Gasoline	ULL Ski Team	500 (max)	AST	Metal Tray	Unknown	Steel	Unknown	Yes	Gauge on tank	No	No
32	Used Cooking Oil/Grease	Vermillionville	500	AST	None	Unknown	Steel with Steel Lid	No	No	Unknown	No	No
33	Diesel	Vermillionville	500	AST	Double- walled	Unknown	Steel	No	No	Unknown	No	No
34	Used Oil	Vermillionville	275	AST	None	1	Steel	No	No	Unknown	No	No

#### APPENDIX B-2 Material Inventory Outside of Airport's Fence

	SPILL	PREVENTION	, CONTROL	, AND COU	APPENDIX B WORKSHEET #2							
		MATERIAL I	NVENTORY	(Potential P	•	ame: Lafayette ast Revision: O						
Material Name of Quantity Type of Containment Age Type of Tank To								Testing of Tanks	Is there Emergency Shutoff (Yes or No)	How are Tanks Gauged	Likelihood of Contact with Storm Water (Yes or No)	Past Significant Spills/Leaks (Yes or No)
35	Fuel drums	Vermillionville	<330 (max)	Drum (6 max)	None	Unknown	Steel	No	No	Visual	Yes	No
36	Diesel	ATCT-FAA	2,000	AST	Double- walled	<5	Concrete	No	No	Visual	No	No
37	Diesel	ASR-FAA	2,000	AST	Double- walled	<5	Concrete	No	No	Visual	No	No
38	Diesel	RTR-FAA	1,000	AST	Double- walled	<5	Concrete	No	No	Visual	No	No
39	Paint Waste, Oil, Fuels, Hydraulic Fluid	Louisiana Technical College Lafayette	<300 (max)	Drums (5 max)	Portable Plastic Container	N/A	Steel/Plastic	N/A	N/A	N/A	No	No
40	Used Cooking Oil	Terminal Restaurant	250	AST	None	1	Steel	No	No	Visual	No	No



## APPENDIX B-3 Prediction and Control of Potential Discharges Inside Airfield

	SPILL PREVENTION, CONT	TROL, AND COUNTERMEASU	APPENDIX B WORKSHEET #3				
	PREDICTION AND CON	TROL OF POTENTIAL DISCH	ARGE	•	afayette Regional A ision: October 15, 2	•	
	Spill Source	Location	Potential Cause	Estimated Quantity (gallons)	Type of Container	Direction of Flow	Rate of Flow
1	Misc. soaps, Paints, Solvents, Oils	Acadian Ambulance	Leak, Rupture	<200 (max)	Small Containers, Aerosol Cans	Contained by Flammable Locker	Variable
2	Soaps, Degreasers, Oils	Acadian Ambulance	Leak, Rupture	440	Totes, Drums	None – Inside Building	Variable
3	Used Oil	Acadian Ambulance	Leak, Rupture	275	Tote	Contained by Portable Plastic Container	Variable
4	Hydraulic/Lube Oils	Frank's Casing Crew (55-gallon Drum Storage Area)	Leak, Rupture	165 (max)	Drums (3 max)	Contained by Stainless Steel Enclosed Container	Variable
5	Used Oil	Frank's Casing Crew	Leak, Rupture	55 (max)	Drum	Contained by Stainless Steel Enclosed Container	Variable
6	Jet Fuel	Frank's Casing Crew	Leak, Rupture, Overfill	12,000 (max)	UST	N/A	Variable
7	LL AvGas	Landmark – Fuel Farm	Leak, Rupture, Overfill	15,000 (max)	AST	Contained by Concrete Dike	Variable
8	Waste Fuel (2)	Landmark – Fuel Farm	Leak, Rupture, Overfill	500	AST	Contained by Concrete Dike	Variable
9	Gasoline	Landmark – Fuel Farm	Leak, Rupture, Overfill	500	AST	Contained by Concrete Dike	Variable
10	Jet Fuel (4)	Landmark – Fuel Farm	Leak, Rupture, Overfill	15,000 (each)	AST	Contained by Concrete Dike	Variable
11	Off Road Diesel	Landmark – Fuel Farm	Leak, Rupture, Overfill	550	AST	Contained by Concrete Dike	Variable
12	LL AvGas	Uphill from Fuel Farm	Leak, Rupture, Overfill	12,000 (max)	AST	Contained by Double-walled Tank	Variable
13	Diesel Fuel (for Emergency Generator)	Federal Aviation Administration	Leak, Rupture, Overfill	2,000 (max)	AST	Contained by Double-walled Tank	Variable
14	Jet Fuel (3)	Landmark	Leak, Rupture, Overfill	5,000	Mobile Fueler	Various; depends on where truck is refueling	Variable

## APPENDIX B-3 Prediction and Control of Potential Discharges Inside Airfield

	SPILL PREVENTION, CONTI	,	APPENDIX B WORKSHEET #3 Facility Name: Lafayette Regional Airport						
	PREDICTION AND CONT	ROL OF POTENTIAL DISCHA	ARGE	•	Date of Last Revision: October 15, 2013				
	Spill Source	Location	Potential Cause	Estimated Quantity (gallons)	Type of Container	Direction of Flow	Rate of Flow		
15	LL AvGas	Landmark	Leak, Rupture, Overfill	1,000	Mobile Fueler	Various; depends on where truck is refueling	Variable		
16	Used Oil	Landmark	Leak, Rupture, Overfill	500	AST	Contained by Metal Tray	Variable		
17	Oil	Landmark	Leak, Rupture, Overfill	<110	Drums	Contained by Metal Tray	Variable		
18	Misc. Soaps, Paints, Solvents, Oils, Hydraulic Fluid	Landmark	Leak, Rupture	<330 (max)	Drums	Containment Pallet	Variable		
19	Gasoline	Landmark	Leak, Rupture, Overfill	100	Mobile Fueler Cart	Various; depends on where truck is refueling	Variable		
20	Diesel	Landmark	Leak, Rupture, Overfill	100	Mobile Fueler Cart	Various; depends on where truck is refueling	Variable		
21	Used Oil (2)	Landmark	Leak, Rupture, Overfill	55	Drums	Containment Pallet	Variable		
22	Diesel Fuel (Vehicle Fueling)	Lafayette Airport Response and Fire Fighting Department	Leak, Rupture, Overfill	500	AST	Contained by Double-walled Tank	Variable		
23	Gasoline	Lafayette Airport Response and Fire Fighting Department	Leak, Rupture, Overfill	500	AST	Contained by Double-walled Tank	Variable		
24	Waste Oil	Lafayette Airport Response and Fire Fighting Department	Leak, Rupture, Overfill	500	AST	Contained by Double-walled Tank	Variable		
25	LL AvGas	Private Aircraft Hangars of Lafayette	Leak, Rupture, Overfill	2,000	AST	Contained by Concrete Dike	Variable		
26	Jet Fuel (2)	Private Aircraft Hangars of Lafayette	Leak, Rupture, Overfill	10,000	AST	Contained by Concrete Dike	Variable		
27	Waste Fuel	Private Aircraft Hangars of Lafayette	Leak, Rupture, Overfill	275	AST	Contained by Concrete Dike	Variable		
28	Waste Oil	UPS Hangar	Leak, Rupture, Overfill	900	AST	Contained by Double-walled Tank	Variable		
29	Used Oil Filters, Oily Rags, Used Oil, Fuel Filters	UPS Hangar	Leak, Rupture, Overfill	275	Drums	Containment Pallet	Variable		

### APPENDIX B-3 Prediction and Control of Potential Discharges Inside Airfield

	SPILL PREVENTION, CONTR	COL, AND COUNTERMEASU	APPENDIX B WORKSHEET #3				
	PREDICTION AND CONTI	ROL OF POTENTIAL DISCH	Facility Name: Lafayette Regional Airport				
				<b>Date of Last Revision:</b> October 15, 2013			
	Spill Source	Location	Potential Cause	Estimated	Type of Container	Direction of Flow	Rate of Flow
				Quantity (gallons)			
30	Oil	55	Transformer	Containment Vault	Variable		
31	31 Jet A Acadian Ambulance Leak, Rupture, Overfill				AST	Contained by	Variable
					Double-walled Tank		

### APPENDIX B-3 Prediction and Control of Potential Discharges Outside of Airport's Fence


	SPILL PREVENTION, CONT	ROL, AND COUNTERMEASU		APPENDIX B WORKSHEET #3				
	PREDICTION AND CONT	FROL OF POTENTIAL DISCH	ARGE	Facility Name: Lafayett Date of Last Revision:	_	-		
	Spill Source	Location	Potential Cause	Estimated Quantity (gallons)	Type of Container	Direction of Flow	Rate of Flow	
1	Diesel	Airport Maintenance	Leak, Rupture, Overfill	500 (max)	AST	Contained by Double-walled Tank	Variable	
2	Gasoline	Airport Maintenance	Leak, Rupture, Overfill	500 (max)	AST	Contained by Double-walled Tank	Variable	
3	Waste Oil	Airport Maintenance	Leak, Rupture, Overfill	500 (max)	AST	Contained by Double-walled Tank	Variable	
4	Misc. Soaps, Paints, Oil	Airport Maintenance	Leak, Rupture	<100 (max)	Small Containers, Aerosol Cans	Contained by Flammable Lockers	Variable	
5	Gasoline	Avis Rent-A-Car	Leak, Rupture, Overfill	5,000 (max)	AST	Contained by Concrete Dike	Variable	
6	Gasoline	Brenton Investments-Shell Station	Leak, Rupture, Overfill	10,000	UST	N/A	Variable	
7	Gasoline (2)	Brenton Investments-Shell Station	Leak, Rupture, Overfill	6,000	UST	N/A	Variable	
8	Diesel	Brenton Investments-Shell Station	Leak, Rupture, Overfill	6,000	UST	N/A	Variable	
9	Misc, Fuels, Oils	Marine Survival Training Center	Leak, Rupture, Overfill	<150 (max)	Drums (2 max)	Contained by Concrete Dike	Variable	
10	Oily Water	Marine Survival Training Center	Leak, Rupture, Overfill	500	AST	Contained by Concrete Dike	Variable	
11	Diesel	Marine Survival Training Center	Leak, Rupture, Overfill	250	AST	Contained by Concrete Dike	Variable	
12	Lubricants, Paint, Soaps	Moss Motors	Leak, Rupture	<100	Small Containers, Aerosol Cans	Contained by Flammable Lockers	Variable	
13	Jet Fuel (2)	PHI Heliport	Leak, Rupture, Overfill	10,000 (each)	AST	Double-walled	Variable	

## APPENDIX B-3 Prediction and Control of Potential Discharges Outside of Airport's Fence

	SPILL PREVENTION, CONTROL,	AND COUNTERMEAS		APPENDIX B WORKSHEET #3					
	PREDICTION AND CONTROL	OF POTENTIAL DISC	· ·	Facility Name: Lafayette Regional Airport  Date of Last Revision: October 15, 2013					
	Spill Source	Location	Potential Cause	Estimated Quantity (gallons)	Type of Container	Direction of Flow	Rate of Flow		
14	WD-40, Methyl Ethyl Ketone	PHI Heliport	Leak, Rupture	<165 (max)	Drums (3 max)	Contained by Spill Containment Pallets	Variable		
15	Used Oil, Hydraulic Fluid	PHI Heliport	Leak, Rupture	<165 (max)	Drums (3 max)	Contained by Spill Containment Pallets	Variable		
16	Used Oil	PHI Main Facility	Leak, Rupture, Overfill	500 (max)	AST	Contained by Double-walled Tank	Variable		
17	Hazardous Materials (Toluene, Methyl Ethyl Ketone, Thinners, Paint Waste)	PHI Main Facility	Leak, Rupture	<660 (max)	Drums (12 max)	Contained by Concrete dike	Variable		
18	Misc. Fuels, Gasoline	PHI Main Facility	Leak, Rupture	<220 (max)	Drums (4 max)	Contained by Concrete dike	Variable		
19	Used Oil	PHI Main Facility	Leak, Rupture	<660 (max)	Drums (12 max)	Contained by Concrete dike	Variable		
20	Jet Fuel	PHI Main Facility	Leak, Rupture, Overfill	2,000	Mobile Fueler	Various; depends on where truck is refueling	Variable		
21	Jet Fuel	PHI Main Facility	Leak, Rupture, Overfill	1,000	Mobile Fueler	Various; depends on where truck is refueling	Variable		
22	Waste Kitchen Grease	PHI Main Facility	Leak, Rupture, Overfill	300	AST	Contained by Spill Containment Pallets	Variable		
23	Jet Fuel	PHI Main Facility	Leak, Rupture, Overfill	500	AST	Contained by Concrete dike	Variable		
24	Jet Fuel	PHI Main Facility	Leak, Rupture, Overfill	1,000	AST	Contained by Double-walled Tank	Variable		
25	Diesel	PHI Main Facility	Leak, Rupture, Overfill	1,000	AST	Contained by Double-walled Tank	Variable		

## APPENDIX B-3 Prediction and Control of Potential Discharges Outside of Airport's Fence

	SPILL PREVENTION, CONTRO	OL, AND COUNTERMEASU		APPENDIX B WORKSHEET #3					
	PREDICTION AND CONTRO	OL OF POTENTIAL DISCH	ARGE		Facility Name: Lafayette Regional Airport  Date of Last Revision: October 15, 2013				
	Spill Source	Location	<b>Potential Cause</b>	Estimated Quantity (gallons)	Type of Container	Direction of Flow	Rate of Flow		
26	Used Oil	National Guard	Leak, Rupture, Overfill	1,000	AST	Contained by Concrete dike	Variable		
27	Diesel	National Guard	Leak, Rupture, Overfill	4,500	AST	Contained by Double-walled Tank	Variable		
28	Diesel	National Guard	Leak, Rupture, Overfill	1,200	Mobile Fueler	Various; depends on where truck is refueling	Variable		
29	Hydraulic, Lube Oils, 15W40, Antifreeze	National Guard	Leak, Rupture	<220 (max)	Drums (4 max)	Contained by Spill Containment Pallets	Variable		
30	Oil, Antifreeze, Transmission Oil	U.S. Navy/Marine Reserves	Leak, Rupture	<275 (max)	Drums (5 max)	Contained by Spill Containment Pallets	Variable		
31	Gasoline	ULL Ski Team	Leak, Rupture, Overfill	500 (max)	AST	Contained by Metal Tray	Variable		
32	Used Cooking Oil/Grease	Vermillionville	Leak, Rupture, Overfill	500	AST	None	Variable		
33	Diesel	Vermillionville	Leak, Rupture, Overfill	500	AST	Contained by Double-walled Tank	Variable		
34	Used Oil	Vermillionville	Leak, Rupture, Overfill	275	AST	None	Variable		
35	Fuel Drums	Vermillionville	Leak, Rupture, Overfill	<330 (max)	Drums (6 max)	None	Variable		
36	Diesel AST	ATCT-FAA	Leak, Rupture, Overfill	2,000	AST	Contained by Double-walled Tank	Variable		
37	Diesel AST	ASR-FAA	Leak, Rupture, Overfill	2,000	AST	Contained by Double-walled Tank	Variable		
38	Diesel AST	RTR-FAA	Leak, Rupture, Overfill	1,000	AST	Contained by Double-walled Tank	Variable		
39	Paint Waste, Oil, Fuels, Hydraulic Fluid	Lafayette Technical College Lafayette	Leak, Rupture	<300 (max)	Drums (5 max)	None – Inside Building	Variable		
40	Used Cooking Oil	Terminal Restaurant	Leak, Rupture, Overfill	250	AST	None	Variable		



APPENDIX B-4
Secondary Containment Capacity Calculations

Tank ID	Stored Material	Maximum Storage Capacity of Single Container	Total Number of Tanks	Tank Construction Type/Material	Area Under a Roof	Secondary Containment Type	Secondary Containment Dimensions (feet)	Secondary Containment Volume (gallons)	% of Maximum Tank Volume
		(gallons)							
Fuel Farm	Jet Fuel/Waste Fuel/Diesel	2 - 15,000/ 1 - 500/ 1 - 550	4	Steel	No	Concrete dike	Areas A, D, and C Below	31,555.1	210
Fuel Farm	LL AvGas/ Jet Fuel/ Waste Fuel/ Gasoline	3 – 15,000 2 – 500	5	Steel	No	Concrete dike	Areas B, E, F, and G Below	51,967.5	346

Area Labeled on	Length	Width	Depth	Total Volume	Number of Areas	Total
Attached	(feet)	(feet)	(feet)	(feet)		Containment of
Diagram						Each Area
						(gallons)
A	32	67.5	1.58	3,412.80	1	25,527.74
В	53	67.5	1.75	6,260.63	1	46,829.48
С	35	10	1.58	553.00	1	4,136.44
D	(0.5)(1	6)(10)	1.58	126.40	2	1,890.94
Е	(0.5)(15.	75)(7.83)	1.75	107.91	1	807.15
F	33.92	7.83	1.75	4664.79	1	3,476.62
G	(0.5)(16.	67)(7.83)	1.75	114.21	1	854.29
					TOTAL	83,522.66

# APPENDIX C PLAN REVIEW CERTIFICATION

## APPENDIX C-1 CERTIFICATION OF SPCC PLAN REVIEW

#### APPENDIX C-1

#### CERTIFICATION OF SPCC PLAN REVIEW

I completed a review and evaluation of the Spill Prevention, Control, and Countermeasure Plan for the Lafayette Regional Airport on <u>12/31/2013</u>, and will amend the Plan as a result.

Signature, Authorized Facility Representative	Date	1/2/14
Gregory M. Roberts, A.A.E.  Name (Printed)		
Director of Aviation Title		

## APPENDIX C-2 RECORD OF PLAN REVIEW AND CHANGE

#### **APPENDIX C-2**

#### RECORD OF PLAN REVIEW AND CHANGES

In accordance with 40 CFR 112.5, the Lafayette Regional Airport (LFT) periodically reviews and evaluates this Spill Prevention, Control, and Countermeasure (SPCC) Plan for any change in the facility design, construction, operation, or maintenance that materially affects the facility's potential for an oil discharge. LFT reviews this SPCC Plan at least once every 5 years. Revisions to the Plan, if any are needed, are made within 90 days of this 5-year review. LFT will implement any amendment as soon as possible, but not later than 90 days following preparation of any amendment. A registered Professional Engineer (PE) certifies any technical amendment to the Plan, as described above, in accordance with 40 CFR 112.3(d). A registered PE will complete a review every 5 years.

Scheduled 5-year reviews and Plan amendments are recorded below. This log must be completed even if no amendment is made to the Plan. Unless a technical or administrative change prompts an earlier review, the next scheduled review of this Plan just occur by December 31, 2018.

Date	Authorized	Review Type	PE	Summary of
	Individual		Certification	Changes
May 2010	Gregory Roberts	ARCADIS	Yes	Update entire plan to
		Update		new regulations
December 2007	Gregory Roberts	ARCADIS	Yes	See 9/7/06 SPCC
		Update		Appendix C
December 2013	Gregory Roberts	C-K Update	Yes	Five-year update –
				changes to conform
				with industry
				standard and to
				include edible oil
				bulk container
				compliance.

# APPENDIX D EMERGENCY RESPONSE PROCEDURES AND CONTACTS

#### EMERGENCY RESPONSE PROCEDURES

#### **Identification of Potential Spill Areas**

The areas at the airport where spills are most likely to occur include refueling of airplanes, the aboveground storage areas, and drum storage area. Spills can occur from the overfilling of tanks or containers, hose or nozzle malfunctions, equipment malfunction or damage, or human error.

#### **Spill Response Procedures and Equipment**

In the case of a spill, employees will perform the following tasks.

- 1. IF AT ALL POSSIBLE, STOP THE SOURCE OF THE SPILL IMMEDIATELY. Close the valve, shut down pumping, right a drum, or take whatever actions are possible to stop any release. Approach the incident area from upwind to a point where the spilled material can be identified.
- 2. Shut down vehicles in the area and fueling equipment at the main or emergency switch as necessary to stop the flow.
- 3. Eliminate all sources of ignition.

ALT PHONE:

- 4. Determine the source, type, and quantity of material spilled.
- 5. After identifying and assessing the hazard, isolate and evacuate the area based on assessment of quantity and threat to life.
- 6. If conditions are hazardous (e.g., fire, potential explosion, or hazardous atmosphere), DO NOT APPROACH. If possible to do so safely, shut down all sources of potential sparks, flames, or heat in the area of the spill.
- 7. As appropriate, call other nearby employees for assistance in stopping the release if their assistance can be provided without endangering themselves or exacerbating the release. Contact the Airport Response and Fire Fighting Department (ARFFD) immediately. As soon as possible, notify the Environmental Site Leader.
- 8. Call the Environmental Site Leader listed below. The Site Leader will designate the appropriate personal safety equipment and additional procedures that must be implemented.

ENVIRONMENTAL SITE LEADER:

CELL PHONE:

337-277-5604

WORK PHONE:

337-266-4401

ARFF Chief

PHONE:

337-233-1651

9. Upon arrival of the Environmental Site Leader, all other response actions will be taken under his or

9. Upon arrival of the Environmental Site Leader, all other response actions will be taken under his or her direction (or the alternate's, if necessary). The Environmental Site Leader will then determine the necessary response actions including whether evacuation of parts or all of the airport are necessary for employee safety. In general, the Environmental Site Leader will direct the containment of the release and decide on alternative source control if the source of the release was not controlled b the person(s) discovering it.

337-266-4461

- 10. The release will be contained to the smallest possible area. Use booms, sandbags, or absorbent pads, or dig small trenches to minimize the extent of the release. If necessary, wood chips, soil, fiberglass mats, sawdust, or scrap paper may be used.
- 11. TAKE IMMEDIATE ACTION TO PREVENT THE SPILL FROM REACHING SURFACE WATERS. Place booms or pads, dig a diversion ditch or ditches, or use soil to build a berm. If the release reaches surface water, attempt to place booms in the water to contain the release or, if necessary, block drainage downstream of the release to prevent further discharge.
- 12. Spill control kits are located in each of the FBO's trucks and at the ARFFD.
- 13. The Environmental Site Leader will determine if the release is a reportable quantity based on the following:
  - a. For releases of hazardous substances onto land the Final Reportable Quantity (RQ) in Table 302.4 in 40 CFR §302.4;
  - b. For releases of hazardous substances into waters of the state the Final RQ in Table 302.4, except when the RQ is greater than 100 pounds, then the RQ shall be 100 pounds;
  - c. For releases of petroleum product, used oil, and oil that is not a petroleum product onto land 210 gallons;
  - d. For releases of spills or discharges into waters of the state quantity sufficient to cause a sheen; and
  - e. For industrial solid waste or other substances into water 100 pounds.
- 14. The Environmental Site Leader will call the appropriate agencies listed on the following page and provide them with the information on the Spill Information Report included in Appendix E.

#### Reporting

If the spill is reportable, the Environmental Site Leader must immediately notify the following, in the order shown:

National Response Center 800-424-8802

Louisiana State Police 225-925-6595

Louisiana Department of Environmental Quality (LDEQ)
Single Point of Contact (SPOC)

225-342-1234

Lafayette Parish Local Emergency Planning Committee 337-236-5895

#### Other Federal and State Agency Contact Numbers:

USEPA Region 6, Dallas, Texas Headquarters	214-655-6444
USEPA Region 6 24-Hr. Hotline	866-372-7745
National Weather Service	817-871-8291
LDEQ Main Office	866-896-5337
LDEQ – Surveillance Division	225-219-3615
LDEQ – Acadian Regional Office	337-262-5584

If the discharge or spill creates an imminent health threat, the responsible person shall immediately notify and cooperate with local emergency response authorities. The Environmental Site Leader will notify one or more of the following appropriate local authorities:

Airport Response & Fire Fighting Department	337-266-4400
---	--------------

Lafayette Fire Department 911 or 337-291-8700

Lafayette Police Department 911 or 337-291-8600

Ambulance 911

# APPENDIX E SPILL INFORMATION REPORT

#### APPENDIX E

#### SPILL INFORMATION REPORT

Time and Date of Spill Discovery:				
Type of Storage/Usage Facility:				
Weather Conditions:				
Description of Spill				
Location of Spill:				
Type of Material Spilled:				
Square Feet of Area Covered:				
Did Spill Flow Off the Site:				
Name of Water Body Affected:				
Estimated Rate of Discharge and Volume Spilled:				
Media Affected:				
Name of Person Discovering Spill:				
Individuals Responding for Spill Control and Cleanup:				
Cause of Spill:				
Damages or Injuries:				
Evacuation Required:				
Containment Method:				
Cleanup Method:				
Contaminated Material Disposal:				
Recommendations to Prevent Similar Future Spills:				
Agencies and Agency Representatives Reported to:				
Spill Report Number from the NRC:				
This report has been prepared by the Environmental Site Leader.				
<del></del>				

(Signature) (Date)

# APPENDIX F INSPECTION FORMS

# APPENDIX F-1 MONTHLY SPCC VISUAL INSPECTION



### **Monthly Visual Tank Inspection**

Summary			
Site Name:	Customer:		
Permit Number:	Inspection Type:		
Permit Description:	Inspector:		
Inspection Date:			
Inspection Notes:			

### **Previous Inspection - Responsive Actions Due**

•	Question	Status	Comments	Responsive Action	Date	Initials
1	List the tanks that were inspected					
2	Is there water in the primary tank, secondary containment, interstice, or spill containment?					
3	Is there any debris or fire hazards in the containment?					
4	Are the drain valves operable and in a closed position?					
5	Are the containment egress pathways clear and gates/doors operable?					
6	Are there visible signs of leakage around the tank, concrete pad, containment, ringwall or ground?					
7	Is the ladder and platform structure secure with no sign of severe corrosion or damage?					
8	Is the tank level gauge readable and in good condition?					
9	Are there other conditions that should be addressed for continued safe operation or that may affect the site SPCC Plan?					
10	Any additional comments					



### **Monthly Visual Tank Inspection**

Signatures	
Inspector:	
Date:	Qualification:
	The above signature also shall certify that this facility is in compliance with the Stormwater Pollution Prevention Plan and the State Generic Permit for Stormwater Discharge from large and small construction activities if there are not any instances of non-compliance identified above.

01/03/2014 Page 2 of 2

# APPENDIX F-2 ANNUAL SPCC INSPECTION



### **Annual SPCC Inspection**

Summary		
Site Name:	Customer:	
Permit Number:	Inspection Type:	
Permit Description:	Inspector:	
Inspection Date:		
Inspection Notes:		

### **Previous Inspection - Responsive Actions Due**

<b>#</b>	Question	Status	Comments	Responsive Action	Date	Initials
1	List all tanks inspected					
2	Are the containment structures in satisfactory condition?					
3	Are drainage pipes/valves fit for continued service?	100 10 10 10 10 10 10 10 10 10 10 10 10				0-0
4	Is there evidence of tank settlement or foundation washout?					
5	Is there any cracking or spalling of the concrete wall or ringwall?			4		
6	Are the tank supports in satisfactory condition?					
7	Is water able to drain away from the tank?					
8	Is the grounding strap secured and in good condition?					
9	Is the Cathodic Protection system functional?					
10	Rectifier reading:					
11	Is there any evidence of paint failure?					
12	Is there any noticeable shell/head distortions, buckling, denting or bulging?					
13	Is there any evidence of shell/head corrosion or cracking?					
14	Are the flanged connection bolts tight and fully engaged with no sign of wear or corrosion?					
15	Is there any standing water on the roof?					
16	Is there any evidence of coating cracking, crazing, peeling or blistering on the tank roof?					
17	Are there any holes in the roof?					



### **Annual SPCC Inspection**

18	Are all vents free of obstructions?	
19	Is the emergency vent operable? Lift as required.	
20	Is any insulation missing?	
21	Are there any noticeable areas of moisture on the insulation?	
22	Is there any mold on the insulation?	
23	Is the insulation exhibiting damage?	
24	Is the insulation sufficiently protected from water intrusion?	
25	Has the tank liquid level sensing device been tested to ensure proper operation?	
26	Does the tank liquid level sensing device operate as required?	
27	Are the overfill prevention devices in proper working condition?	
28	Are tank grounding lines in good condition?	
29	Is the electrical wiring for control boxes/lights in good condition?	
30	Is the electrical wiring for control boxes/lights in good condition?	
31	Is the electrical wiring for control boxes/lights in good condition?	
32	Additional comments	
32	Additional comments	

Signatures	
Inspector:	
Date:	Qualification:
	The above signature also shall certify that this facility is in compliance with the Stormwater Pollution Prevention Plan and the State Generic Permit for Stormwater Discharge from large and small construction activities if there are not any instances of non-compliance identified above.